


# Programmable DC Electronic Load

## Series IT8800 User's Manual



Model: IT8813/IT8813B/IT8813C/  
IT8814/IT8814B/IT8814C/  
IT8816/IT8816B/IT8817/IT8817B/  
IT8818/IT8818B  
Revision: V3.7

## Statement

According to the international copyright law, reproduction of any part of this manual in any form (including electronic storage and retrieval or translation into languages of other countries or regions) is not allowed without prior permission and written consent of Itech Electronic Co., Ltd.

### Manual Article No.

IT8800

### Revision

Revision 3, published on

September 10, 2025

Itech Electronic, Co., Ltd.

### Trademark Statement

Pentium is a registered trademark of Intel Corporation in the United States.

Microsoft, Visual Studio, Windows and MS Windows are trademarks of Microsoft Corporation in the United States and/or other countries/regions.

### Guarantee

Materials in the document are provided *talīs qualīs* and may be changed in future revisions without prior notice. In addition, within the maximum allowable extent of laws, ITECH is not committed to any explicit or implied guarantee for this manual and all information therein, including but not limited to the implied guarantee on marketability and availability for some special purposes. ITECH shall not be responsible for any error or incidental or indirect losses caused by the provision, use or application of this documents and information therein. If some guarantee clauses in other written agreements between ITECH and users are not consistent with clauses herein, those clauses in other written agreements shall prevail.

### Technology license

Hardware and/or software in this document cannot be provided without a license and can only be used or copied according to the license.

### Restricted permission statement

Restricted permissions of the U.S. government. Permissions for software and technical data which are authorized to the U.S. Government only include those for custom provision to end users. ITECH follows FAR 12.211 (technical data), 12.212 (computer software). DFARS 252.227-7015 (technical data--commercial products) for national defense and DFARS 227.7202-3 (permissions for commercial computer software or computer software documents) while providing the customized business licenses of software and technical data.

### Safety Statement

#### CAUTION

“Caution” signs indicate danger. It is required to pay attention to the contents of these signs during implementation of operations.

The damage to the product or loss of important data may be caused in case of improper operation steps or failure to follow operation steps. Do not continue to implement any improper operation indicated in “Caution” signs when the specified conditions are not fully understood or these conditions are not satisfied.

#### WARNING

“Warning” indicates danger. It is required to pay attention to the contents of these signs during implementation of operation steps. Personal casualties may be caused in case of improper operation steps or failure to follow these operation steps. Do not continue to implement any improper operation indicated in “Warning” signs when the specified conditions are not fully understood or these conditions are not satisfied.



#### NOTE

“Instructions” indicates operation instructions. It is required to refer to the contents of these signs during operation steps. These signs are used for providing tips or supplementary information for operators.

## Certification and Quality Assurance

IT8800 series electronic load completely reaches nominal technical indicators in the manual.

## Warranty service

ITECH Company will provide one-year warranty services for the product materials and manufacturing (excluding the following limitations).

- When warranty service or repair is needed, please send the product to the service unit specified by ITECH Company.
- When the product is sent to ITECH Company for warranty service, the customer must pay the one-way freight to the maintenance department of ITECH, and ITECH will be responsible for return freight.
- If the product is sent to ITECH for warranty service from other countries, the customer will be responsible for all the freight, duties and other taxes.

## Limitation of Warranty

Warranty service does not apply to the damage caused in the following circumstances:

- Damage resulting from customer-wired circuits or customer-supplied parts or accessories;
- Product which has been modified or repaired by the customer;
- Damage caused by the circuit installed by the customer or damage caused by operation of the product in non-specified environment;
- The product model or serial number is altered, deleted, removed or made illegible by customer;
- Damage caused by accidents, including but not limited to lightning, water, fire, abuse or negligence.

## Safety signs

|                                                                                     |                                                                                   |                                                                                       |                                          |
|-------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------|---------------------------------------------------------------------------------------|------------------------------------------|
|  | DC power                                                                          |  | ON (with the power switched on)          |
|  | AC power                                                                          |   | OFF (with the power supply switched off) |
|  | Both DC and AC power supply                                                       |   | Power supply switching-on status         |
|  | Protective grounding terminal                                                     |   | Power supply switching-off status        |
|  | Grounding terminal                                                                |   | Reference terminal                       |
|  | Danger sign                                                                       |   | Positive terminal                        |
|  | Warning sign (refer to specific "Warning" or "Caution" information in the manual) |   | Negative terminal                        |
|  | Ground wire connection end sign                                                   | -                                                                                     | -                                        |

## Safety Precautions

General safety precautions below must be followed in each phase of instrument operation. In case of failure to follow these precautions or specific warnings in other parts of the manual, violation against the safety standards related to the design, manufacture and purpose of the instrument will occur. If the user does not follow these precautions, ITECH will bear no responsibility arising there from.

### WARNING

- The electronic load is provided with a three-core power line during delivery and should be connected to a three-core junction box. Before operation, be sure that the electronic load is well grounded.
- Use electric wires of appropriate load. All loading wires should be capable of bearing maximum short-circuit of electronic load without overheating.
- Ensure the voltage fluctuation of mains supply is less than 10% of the working voltage range in order to reduce risks of fire and electric shock.
- To prevent burnout, please pay special attention to positive and negative polarities of electronic load during connection!
- Do not use damaged equipment. Please check the housing before using the equipment. Check whether the instrument is subject to cracking or is lack of plastic. Do not operate the instrument in the environment with explosive gas, steam or dust.
- Observe all tags on the equipment before connection.
- Do not install alternative parts on the instrument or perform any unauthorized modification.
- Do not use the equipment when the removable cover is dismantled or loose.
- Please use the power adapter supplied by the manufacturer to avoid accidental injury.
- We do not accept responsibility for any direct or indirect financial damage or loss of profit that might occur when using the instrument.
- This instrument is used for industrial purposes. Do not apply this product to IT power supply system.
- Do not use the equipment on the life support system or other equipment with safety requirements.

### CAUTION

- If the equipment is not used in the manner specified by the manufacturer, its protection may be damaged.
- Always use dry cloth to clean the equipment housing. Do not clean the inside of the instrument.
- Do not block the air vent of the equipment.

## Environmental conditions

The IT8800 series electronic load can only be used indoors or in low condensation areas. The following table shows general environmental requirements for this instrument.

| Environmental conditions | Requirement                |
|--------------------------|----------------------------|
| Operating temperature    | 0°C~40°C<br>0°C - 40°C     |
| Operating humidity       | 20% - 80% (non condensing) |
| Storage temperature      | -20°C - 70 °C              |

Altitude  
Installation category  
Pollution degree

Operating up to 2,000 meters  
II  
Pollution degree 2



#### NOTE

In order to ensure the accuracy of measurement, it is recommended to operate the instrument half an hour after start-up.

## Regulation tag

|                                                                                     |                                                                                                                                                                                                                                                                                                                                              |
|-------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
|    | <p>The CE tag shows that the product complies with the provisions of all relevant European laws (if the year is shown, it indicates that the year when the design is approved).</p>                                                                                                                                                          |
|    | <p>The UKCA tag shows that the product complies with the provisions of all relevant United Kingdom laws (if the year is shown, it indicates that the year when the design is approved).</p>                                                                                                                                                  |
|   | <p>This instrument complies with the WEEE directive (2002/96/EC) tag requirements. This attached product tag shows that the electrical/electronic product cannot be discarded in household waste.</p>                                                                                                                                        |
|  | <p>This symbol indicates that no danger will happen or toxic substances will not leak or cause damage in normal use within the specified period. The service life of the product is 10 years. The product can be used safely within the environmental protection period; otherwise, the product should be put into the recycling system.</p> |

## Waste electrical and electronic equipment (WEEE) directive



Waste electrical and electronic equipment (WEEE) directive, 2002/96/EC

The product complies with tag requirements of the WEEE directive (2002/96/EC). This tag indicates that the electronic equipment cannot be disposed of as ordinary household waste.

Product Category

According to the equipment classification in Annex I of the WEEE directive, this instrument belongs to the "Monitoring" product.

If you want to return the unnecessary instrument, please contact the nearest sales office of ITECH.

## Compliance Information

Complies with the essential requirements of the following applicable European Directives, and carries the CE marking accordingly:

- Electromagnetic Compatibility (EMC) Directive 2014/30/EU
- Low-Voltage Directive (Safety) 2014/35/EU

Conforms with the following product standards:

### EMC Standard

IEC 61326-1:2012/ EN 61326-1:2013 <sup>123</sup>

#### Reference Standards

CISPR 11:2009+A1:2010/ EN 55011:2009+A1:2010 (Group 1, Class A)

IEC 61000-4-2:2008/ EN 61000-4-2:2009

IEC 61000-4-3:2006+A1:2007+A2:2010/ EN 61000-4-3:2006+A1:2008+A2:2010

IEC 61000-4-4:2004+A1:2010/ EN 61000-4-4:2004+A1:2010

IEC 61000-4-5:2005/ EN 61000-4-5:2006

IEC 61000-4-6:2008/ EN 61000-4-6:2009

IEC 61000-4-11:2004/ EN 61000-4-11:2004

1. The product is intended for use in non-residential/non-domestic environments. Use of the product in residential/domestic environments may cause electromagnetic interference.
2. Connection of the instrument to a test object may produce radiations beyond the specified limit.
3. Use high-performance shielded interface cable to ensure conformity with the EMC standards listed above.

### Safety Standard

IEC 61010-1:2010/ EN 61010-1:2010

## Content

|                                                                  |           |
|------------------------------------------------------------------|-----------|
| CERTIFICATION AND QUALITY ASSURANCE .....                        | I         |
| WARRANTY SERVICE .....                                           | I         |
| LIMITATION OF WARRANTY .....                                     | I         |
| SAFETY SIGNS .....                                               | I         |
| SAFETY PRECAUTIONS .....                                         | II        |
| ENVIRONMENTAL CONDITIONS .....                                   | II        |
| REGULATION TAG .....                                             | III       |
| WASTE ELECTRICAL AND ELECTRONIC EQUIPMENT (WEEE) DIRECTIVE ..... | III       |
| COMPLIANCE INFORMATION .....                                     | IV        |
| <b>CHAPTER1 ACCEPTANCE AND INSTALLATION .....</b>                | <b>1</b>  |
| 1.1 CONFIRM PACKAGE CONTENTS .....                               | 1         |
| 1.2. INSTALLATION POSITION .....                                 | 2         |
| 1.3 INSTALLATION OF POWER LINE .....                             | 4         |
| <b>CHAPTER2 QUICK START .....</b>                                | <b>5</b>  |
| 2.1 BRIEF INTRODUCTION .....                                     | 5         |
| 2.2 INTRODUCTION OF FRONT PANEL .....                            | 6         |
| 2.3 INTRODUCTION TO THE KEYPAD .....                             | 6         |
| 2.4 FAST FUNCTION KEY .....                                      | 7         |
| 2.5 FUNCTION DESCRIPTION OF VFD STATUS INDICATORS.....           | 8         |
| 2.6 INTRODUCTION OF REAR PANEL .....                             | 9         |
| 2.7 POWER-ON SELFTEST .....                                      | 10        |
| <b>CHAPTER3 FUNCTION AND FEATURES.....</b>                       | <b>13</b> |
| 3.1 SWITCHING OF LOCAL/REMOTE OPERATION MODES .....              | 13        |
| 3.2 CONSTANT-STATUS OPERATION MODE.....                          | 13        |
| 3.2.1 Constant current operation mode (CC) .....                 | 14        |
| 3.2.2 Constant voltage operation mode (CV).....                  | 15        |
| 3.2.3 Constant resistance operation mode (CR).....               | 16        |
| 3.2.4 Constant power operation mode (CW) .....                   | 17        |
| 3.3 INPUT CONTROL FUNCTION.....                                  | 18        |
| 3.4 KEYBOARD LOCKING FUNCTION .....                              | 18        |
| 3.5 SHORT-CIRCUIT ANALOG FUNCTION.....                           | 18        |
| 3.6 SYSTEM MENU FUNCTION (SYSTEM) .....                          | 18        |
| 3.7 CONFIGURATION MENU FUNCTION (CONFIG) .....                   | 20        |
| 3.8 TRIGGERING FUNCTION.....                                     | 21        |
| 3.9 DYNAMIC TEST FUNCTION .....                                  | 22        |
| 3.9.1 Continuous mode .....                                      | 22        |
| 3.9.2 Pulse mode.....                                            | 23        |
| 3.9.3 Toggle mode.....                                           | 25        |
| 3.10 OCP TEST FUNCTION.....                                      | 26        |
| 3.11 OPP TEST FUNCTION.....                                      | 27        |
| 3.12 BATTERY DISCHARGE TEST FUNCTION .....                       | 28        |
| 3.13 CR-LED TEST FUNCTION.....                                   | 29        |
| Setting CR-LED Mode .....                                        | 30        |

|                                                                      |           |
|----------------------------------------------------------------------|-----------|
| 3.14 MEASUREMENT OF VOLTAGE RISE TIME .....                          | 31        |
| 3.15 CONFIGURATION SAVE FUNCTION.....                                | 32        |
| 3.16 VON FUNCTION.....                                               | 33        |
| 3.17. PROTECTIVE FUNCTION .....                                      | 34        |
| 3.17.1 Over-voltage protection (OVP).....                            | 34        |
| 3.17.2 Over-current protection (OCP) .....                           | 34        |
| 3.17.3 Over-power protection (OPP).....                              | 35        |
| 3.17.4 Over-temperature protection (OTP).....                        | 35        |
| 3.18 LIST OPERATION (LIST).....                                      | 36        |
| 3.19 TERMINAL FUNCTION OF REAR BOARD .....                           | 38        |
| 3.19.1 Remote sense compensation functions.....                      | 38        |
| 3.19.2 External trigger operation.....                               | 39        |
| 3.19.3 External analog test .....                                    | 39        |
| 3.19.4 External On/Off Control .....                                 | 39        |
| 3.19.5 Voltage fault indication terminal .....                       | 40        |
| 3.19.6 Current monitoring (I Monitor).....                           | 40        |
| 3.20 EXTERNAL SIGNAL CONTROL INTERFACE.....                          | 40        |
| 3.21 AUTO TEST FUNCTION.....                                         | 41        |
| <b>CHAPTER4     TECHNICAL SPECIFICATIONS .....</b>                   | <b>45</b> |
| 4.1 MAJOR TECHNICAL PARAMETERS .....                                 | 45        |
| 4.2 ADDITIONAL FEATURES .....                                        | 53        |
| <b>CHAPTER5     REFERENCES OF LOAD COMMUNICATION INTERFACES.....</b> | <b>55</b> |
| 5.1 RS232 INTERFACE .....                                            | 55        |
| 5.2 USB INTERFACE .....                                              | 56        |
| 5.3 GPIB INTERFACE(ONLY FOR IT8800(G) SERIES).....                   | 57        |
| <b>APPENDIX.....</b>                                                 | <b>58</b> |
| SPECIFICATIONS OF RED AND BLACK TEST LINES .....                     | 58        |

# Chapter1 Acceptance and Installation

## 1.1 Confirm package contents

Open the package and check the articles within package box before operation. In case of any non-conformity, missing or appearance wearing, please contact ITECH immediately.

Table 1-1 Package box contents (to a machine as a reference standard)

| Device name            | Quantity | Model                               | Remarks                                                                                                                                                                                                     |
|------------------------|----------|-------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Electronic load        | 1        | IT8800 series                       | IT8800 series include:<br>IT8813/ IT8813B/<br>IT8813C/ IT8814C/<br>IT8814/ IT8814B/<br>IT8816/ IT8816B/<br>IT8817/ IT8817B/<br>IT8818/ IT8818B                                                              |
| Power cord             | x        | IT-E171/IT-E172/<br>IT-E173/IT-E174 | Number of the power cords vary depending on the model. The User may select different power lines based on local outlet specification. For detailed specifications, refer to 1.3 Installation of Power Line. |
| Calibration Report     | 1        | -                                   | Test report before delivery.                                                                                                                                                                                |
| USB communication line | 1        | -                                   | -                                                                                                                                                                                                           |




### NOTE

After confirming that package contents are consistent and correct, please appropriately keep package box and related contents. The package requirements should be met when the instrument is returned to factory for repair.


## 1.2. Installation position

The instrument should be installed at well-ventilated and rational-sized space. Please select appropriate space for installation based on the electronic load size.


**Model:** IT8813/IT8813C/IT8814/IT8816/IT8813B/IT8814B/IT8816B/IT8814C




### Detailed dimensional drawings



**Model:** IT8817/IT8817B/IT8818/IT8818B



### Detailed dimensional drawings



## 1.3 Installation of power line

Connect power line of standard accessories and ensure that the electronic load is under normal power supply.


### AC power input level

Working voltage of IT8800 series includes 110V and 220V (which can be selected by the switch on rear board of load). When IT8800 series load power is greater than or equal to 35KW, the 110V AC power input is not supported. AC power input level:

- Option Opt.1: 220Vac 50Hz/60Hz
- Option Opt.2: 110Vac 50Hz/60Hz

### Categories of power lines


Please select appropriate power lines appropriate to local voltage based on the specifications of power lines below. If purchased model fails to meet local voltage requirements, please contact distributor or factory for change.



China  
IT-171



America, Canada,  
Japan  
IT-E172



Europe  
IT-E173



Britain  
IT-E174

## Chapter2 Quick Start

This Chapter will introduce power-on check steps of IT8800 Series to ensure normal start-up and usage under initialization status of the load. Besides, to facilitate usage, this part also displays the functions of front board, rear board and keyboard keys as well as display functions of VFD (Vacuum Fluorescent Display) to a quick view of load appearance, structure and key usage functions before operation.

### 2.1 Brief introduction

IT8800 series has wide power range 150W~6kW, voltage and current measurement speed up to 50KHZ, resolution up to 0.1mV/0.01mA, adjustable measurement current rising speed 0.001A/us~2.5A/us, built-in RS232 /USB interface. IT8800 series has wide application fields because of its high performance products, it has been applied to LED lighting, automotive electronics and other fields.

This Series delivers special functions and advantages at international level, including:

- High-visibility vacuum fluorescent display (VFD)
- Dynamic mode: up to 25KHz
- Voltage measurement dissolution rate: up to 0.1 mV Current 0.01 mA (10 uA)
- Voltage and current measurement speed: up to 50 KHz
- Four operation modes: constant voltage, constant current, constant resistance and constant power.
- Rotary coding switch for easy and quick operation
- Remote sense function
- Battery test function
- OCP test, OPP test
- Auto test function
- CR-LED test
- Memory capacity: 100 groups
- Short-circuit function
- Dynamic test function
- Portable and robust enclosure equipped with skid resistant foot stand
- Intelligent fan control
- Built-in Buzzer, for warning
- Outage backup memory
- Built-in USB and RS232 communication interfaces

Model Selection Table for IT8800 Series:

| Model   |            | Voltage | Current | Power | Height |
|---------|------------|---------|---------|-------|--------|
| IT8813  | IT8813(G)  | 120V    | 60A     | 750W  | 3U     |
| IT8813B | IT8813B(G) | 500V    | 30A     | 750W  | 3U     |
| IT8813C | IT8813C(G) | 120V    | 120A    | 750W  | 3U     |
| IT8814  | IT8814(G)  | 120V    | 120A    | 1500W | 3U     |

| Model   |            | Voltage | Current | Power | Height |
|---------|------------|---------|---------|-------|--------|
| IT8814B | IT8814B(G) | 500V    | 60A     | 1200W | 3U     |
| IT8814C | IT8814C(G) | 120V    | 240A    | 1500W | 3U     |
| IT8816  | IT8816(G)  | 120V    | 240A    | 3000W | 3U     |
| IT8816B | IT8816B(G) | 500V    | 100A    | 2500W | 3U     |
| IT8817  | IT8817(G)  | 120V    | 360A    | 4500W | 6U     |
| IT8817B | IT8817B(G) | 500V    | 120A    | 3600W | 6U     |
| IT8818  | IT8818(G)  | 120V    | 480A    | 6000W | 6U     |
| IT8818B | IT8818B(G) | 500V    | 150A    | 5000W | 6U     |




#### NOTE

IT8800(G) is the model with built-in GPIB, the function is the same as standard model, please check with ITECH for availability.

## 2.2 Introduction of front panel


Front panel introduction of IT8813/IT8814/IT8816/IT8813B/IT8814B/IT8816B/IT8813C/IT8814C, and front panel introduction of IT8817/IT8817B/IT8818/IT8818B as below except cooling window.



1. Power switch
2. VFD screen
3. Adjusting knob
4. Function keys
5. Numeric keys, Esc keys and composite keys
6. Arrow Keys and Enter Key

## 2.3 Introduction to the keypad

The keypad of IT8800 series is shown in the next figure.



The following table explains the keys and buttons on the keypad.

|                                                                                                |                                                                             |
|------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------|
| <b>Shift</b>                                                                                   | Enables access to secondary functions.                                      |
| <b>Recall</b>                                                                                  | Recalls stored instrument setting.                                          |
| <b>Tran</b>                                                                                    | Configures transient parameters.                                            |
| <b>Trig</b>                                                                                    | Sets the load to trigger mode for list and transient function.              |
| <b>List</b>                                                                                    | Configures list parameters.                                                 |
| <b>Pause</b>                                                                                   | To pause operation during automatic test.                                   |
| <b>CC</b>                                                                                      | Sets the load to CC mode and configures the current value.                  |
| <b>CV</b>                                                                                      | Sets the load to CV mode and configures the voltage value.                  |
| <b>CR</b>                                                                                      | Sets the load to CR mode and sets the resistance value.                     |
| <b>CW</b>                                                                                      | Sets the load to CW mode and configures the power value.                    |
| <b>Enter</b>                                                                                   | Confirms settings.                                                          |
| <b>On/Off</b>                                                                                  | Turns the instrument on or off.                                             |
|             | Up key, to select menu items during menu operation.                         |
|             | Down key, to select menu items during menu operation.                       |
|             | Right key, to adjust the cursor to the specified location to set the value. |
|             | Left key, to adjust the cursor to the specified location to set the value.  |
| <b>OK</b>                                                                                      | Confirms settings.                                                          |
| <b>0-9</b>                                                                                     | Enters numeric values for various parameters.                               |
| <b>.</b>                                                                                       | Decimal point.                                                              |
| <b>ESC</b>                                                                                     | Cancels the current action and returns to the previous menu.                |
|  <b>x10</b> | Rotary knob to adjust the setups by 10 stepping.                            |
|  <b>x1</b>  | Rotary knob to adjust the setups by 1 stepping.                             |

## 2.4 Fast function key

A combination of front board keys and Shift composition keys in IT8800 Series can realize functions marked at key bottom. For details, see table below.

|                        |                                     |
|------------------------|-------------------------------------|
| <b>Shift+1 (Short)</b> | To start or end short circuit test. |
|------------------------|-------------------------------------|


|                           |                                                                                                           |
|---------------------------|-----------------------------------------------------------------------------------------------------------|
| <b>Shift +2 (program)</b> | Auto test function.                                                                                       |
| <b>Shift +3 (Battery)</b> | Battery test function.                                                                                    |
| <b>Shift +4 (Save)</b>    | To save existing setting load parameter values, e.g., voltage, current and power.                         |
| <b>Shift +5 (System)</b>  | To set system menu.                                                                                       |
| <b>Shift +6 (Config)</b>  | To configure system menu.                                                                                 |
| <b>Shift +7 (Info)</b>    | To display model, version number and serial number of electronic load.                                    |
| <b>Shift +8 (Lock)</b>    | Keyboard locking function.                                                                                |
| <b>Shift +9 (Local)</b>   | LOCAL key, to shift local and remote operation.                                                           |
| <b>Shift + CC (OCP)</b>   | OCP test function.                                                                                        |
| <b>Shift + CV (Setup)</b> | To set specific parameters of constant voltage, constant current, constant resistance and constant power. |
| <b>Shift + CW (OPP)</b>   | OPP test function.                                                                                        |

## 2.5 Function description of VFD status indicators


|             |                                                                            |              |                                                            |
|-------------|----------------------------------------------------------------------------|--------------|------------------------------------------------------------|
| <b>OFF</b>  | The load is off.                                                           | <b>Error</b> | The load has error.                                        |
| <b>CC</b>   | The load is under constant current mode.                                   | <b>Trig</b>  | The load is waiting for triggering signal.                 |
| <b>CV</b>   | The load is under constant voltage mode.                                   | <b>Sense</b> | The load is under remote sense input mode.                 |
| <b>CR</b>   | The load is under constant resistance mode.                                | <b>Prot</b>  | The load is under software over-current protection status. |
| <b>CW</b>   | The load is under constant power mode.                                     | <b>Rear</b>  | Start external analog quantity function.                   |
| <b>Rmt</b>  | The load is under remote operation mode.                                   | <b>Auto</b>  | Start automatic voltage range.                             |
| <b>Addr</b> | Send command under remote operation.                                       | *            | Start keyboard locking function                            |
| <b>SRQ</b>  | Serial request query.                                                      | <b>Shift</b> | Shift key is pressed.                                      |
| <b>LRV</b>  | LRV will be displayed on the screen when the load input reverses polarity. | -            | -                                                          |

## 2.6 Introduction of rear panel


- Rear panel of IT8813/IT8814/IT8813B/IT8814B/IT8813C/IT8814C.



- Rear panel of IT8816/IT8816B.




- Rear panel of IT8817/IT8817B.



1. Input terminal
2. Current detection terminal
3. Remote sense compensation terminal, external triggering terminal and external analog 0-10V control terminal.
4. External signal control interface
5. RS232 communication cable interface
6. USB communication cable interface
7. GPIB communication cable interface (Only for IT8800(G) series.)

8. AC power switch key
9. AC power input socket (including fuse)

- Rear panel of IT8818/IT8818B.



1. Input terminal
2. Current detection terminal
3. Remote sense compensation terminal, external triggering terminal and external analog 0-10V control terminal.
4. External signal control interface
5. RS232 communication cable interface
6. USB communication cable interface
7. GPIB communication cable interface (Only for IT8800(G) series.)
8. AC power switch key
9. AC power input socket (including fuse)

## 2.7 Power-on selftest

A successful self-test indicates that the purchased load product meets delivery standards and is available for normal usage.

Before operation, please confirm that you have fully understood the safety instructions.

### WARNING

- To avoid burning out, be sure to confirm that power voltage matches with supply voltage.
- Be sure to connect the main power socket to the power outlet of protective grounding. Do not use terminal board without protective grounding. Before operation, be sure that the electronic load is well grounded.
- To avoid burning out, pay attention to marks of positive and negative

## polarities before wiring.

### Self-test steps


Normal self-test procedures:

1. Correctly connect the power line. Press **Power** key to start up.  
The VFD screen of electronic load displays software version number "**BOIS Ver. 1.10**".
2. After approximate 1s, the system is under self-test and the VFD display shows "**System Self-test...**"
3. After self-test, the VFD display information below.  
**0.0000V 0.0000A**  
**0.00W CC=0.000A**  
**Information description:**
  - The first line displays actual input voltage and current values.
  - The second line displays setting values of actual power value and current (voltage, power and resistance).
4. Press **[Shift] + 7 (Info)**, the electronic load VFD screen displays related information of the product. Press   key to switch display of product model, product serial number and software version number.  
Model: IT88XX  
Ver.: 1.XX-1.XX  
SN: XXXXXXXXXXXXXXXXXXXX

### Exception handling

If the electronic load cannot start normally, please check and take measures by reference to steps below.


1. Check whether the power line is correctly connected and confirm whether the electronic load is powered.  
Correct wiring of power line => 2  
Incorrect wiring of power line => Re-connect the power line and check whether the exception is removed.
2. Check whether the power in On. **Power** key is under "I" On status.  
Yes => 3  
No => Please check the **Power** key to start power and check whether the exception is removed.
3. Check whether set power voltage of electronic load is larger than the power supply voltage. If set power voltage is 220 V and the supply voltage is 110V, the electronic load cannot start.
4. Check whether the fuse of electronic fuse is burned out.  
If yes, change fuse. Detailed steps:
  - 1) Pull out power line and take out the fuse box at power line jack with a small screw driver. As shown below.



- 2) If the fuse is fused, please change fuse of same specification based on machine model. See the table below for matching information of fuse and machine model.

| Products       | Specification (110VAC) | Specification (220VAC) |
|----------------|------------------------|------------------------|
| IT8813/13B/13C | T 3.15A 250VAC         | T 1.6A 250VAC          |
| IT8814/14B/14C | T 3.15A 250VAC         | T 1.6A 250VAC          |
| IT8816/16B     | T 3.15A 250VAC         | T 1.6A 250VAC          |
| IT8817/17B     | T 5A 250VAC            | T 2.5A 250VAC          |
| IT8818/18B     | T 5A 250VAC            | T 2.5A 250VAC          |

- 3) After replacement, install the fuse box back to original position, as shown below.



## Chapter3 Function and Features

---

This Chapter will give a detailed description of functions and features of the electronic load. It is divided into the following parts:

- Switching of local/remote operation modes
- Constant-status operation mode
- Input control function
- Keyboard locking function
- Dynamic simulation function
- System menu function
- Configuration menu function
- Triggering function
- Dynamic test function
- OCP test function
- OPP test function
- Battery discharge test function
- CR-LED function
- Measurement of voltage rise time
- Save function
- VON function
- Protective function
- List function
- Terminal function of rear board
- Auto test function

### 3.1 Switching of local/remote operation modes

The electronic load is provided with local and remote operation modes. These two modes can be switched through communication commands. At initialization, the electronic load is defaulted under local operation mode.

- **Local operation mode:** for operating related functions through keys on the electronic load machine.
- **Remote operation mode:** for operating related functions of the electronic load on PC through a connection between the electronic load and PC. Under remote operation mode, except **[Shift] + 9 (Local)** keys, other keys on the board are disabled. The **[Shift] + 9 (Local)** key can be used for switching to local operation mode.

### 3.2 Constant-status operation mode

The electronic mode can work under the 4 constant-state operation modes:

- Constant current operation mode (CC)
- Constant voltage operation mode (CV)
- Constant resistance operation mode (CR)

- Constant power operation mode (CW)

### 3.2.1 Constant current operation mode (CC)

Under CC mode, the electronic load will consume constant current in regardless of whether the input voltage changes or not, as shown in Fig. 3-1.




Fig. 3-1 Voltage-Current Relation Schema under CC Mode

Under CC mode, the electronic load provides three ways to set constant current.

- Under CC mode, rotate the pulse knob to change constant current value.
- Under CC mode, directly input numeric key and press **[Enter]** key for confirmation to change constant current value.
- Under CC mode, move the cursor with Left/Right Key and press Left/Right Key to adjust value at corresponding position.

#### Operation steps

1. Press **[CC]** key and **[Shift] + [CV]** to enter parameter setting screen.  
Constant Current  
Range=0.000A
2. Set maximum working current value and press **[Enter]** key.  
Constant Current  
Range =1.000A
3. Set maximum voltage value and press **[Enter]** key.  
Constant Current  
High=0.00V
4. Set minimum voltage value and press **[Enter]** key for confirmation.  
Constant Current  
Low=0.000V
5. Set high and low rate and press **[Enter]** key for confirmation.  
Constant Current  
High-Rate Low-Rate
6. Set ascending slope and press **[Enter]** key for confirmation.  
Constant Current  
Rise up=0.000A/uS
7. Set descending slope and press **[Enter]** key for confirmation.

Constant Current  
Rise down=0.000A/uS

8. Complete parameter setting.

10.0000V 0.0000A  
0.00W CC=1.000A



NOTE

If the above method is for editing auto test step (as mentioned below), constant current range can also be set.

### 3.2.2 Constant voltage operation mode (CV)

Under CV mode, the electronic load will consume sufficient current to maintain the input voltage at setting voltage. As shown in Fig. 3-2.




Fig. 3-2 Voltage-Current Relation Schema under CV Mode

Under CV mode, the electronic load provides three ways to modify constant voltage.

- Under CV mode, rotate the pulse knob to change constant voltage value.
- Under CV mode, directly input numeric key and press **[Enter]** key for confirmation to change constant voltage value.
- Under CV mode, move the cursor with Left/Right Key and press Left/Right Key to adjust value at corresponding position.

#### Operation steps

1. Press **[CV]** key and **[Shift] + [CV]** to enter parameter setting screen.  
Constant Voltage  
Range=120.00V
2. Set maximum working voltage value and press **[Enter]** key for confirmation.  
Constant Voltage  
Range=2.33V
3. Set maximum current value and press **[Enter]** key for confirmation.  
Constant Voltage  
High=66.000A

4. Set minimum current value and press **[Enter]** key for confirmation.

Constant Voltage

Low=0.0000A

5. Complete parameter setting.

10.0000V 0.0000A

0.00W CV=2.33V



#### NOTE

If the above method is for editing auto test step (as mentioned below), constant voltage range can also be set.

### 3.2.3 Constant resistance operation mode (CR)

Under CR mode, the electronic load is equivalent to a constant resistance (as shown below) and will give linear change of current with input voltage change. As shown in Fig. 3-3:




Fig. 3-3 Voltage-Current Relation Schema under CR Mode

Under CR mode, the electronic load provides three ways to modify constant resistance.

- Under CR mode, rotate the pulse knob to change constant resistance value.
- Under CR mode, directly input numeric key and press **[Enter]** key for confirmation to change constant resistant value.
- Under CR mode, move the cursor with Left/Right Key and press Left/Right Key to adjust value at corresponding position.

#### Operation steps

1. Press **[CR]** key and **[Shift] + [CV]** to enter parameter setting screen.  
Constant Resistance  
Range=7500.0Ω
2. Set maximum working resistance value and press **[Enter]** key.  
Constant Resistance  
Range =2Ω
3. Set maximum voltage value and press **[Enter]** key.

Constant Resistance

High=130.0V

4. Set minimum voltage value and press **[Enter]** key for confirmation.

Constant Resistance

Low=0.000V

5. Complete parameter setting.

10.0000V 0.0000A

0.00W CR=2.000Ω



#### NOTE

If the above method is for editing auto test step (as mentioned below), constant resistance range can also be set.

### 3.2.4 Constant power operation mode (CW)

Under CW mode, the electronic load will consume a constant power, as shown below. If input voltage rises, the input current decreases and power  $P (= V * I)$  will maintain at setting power. As shown in Fig. 3-4:




Fig. 3-4 Voltage-Current Relation Schema under CW Mode

Under CW mode, the electronic load provides three ways to modify constant power.

- Under CW mode, rotate the pulse knob to change constant power value.
- Under CW mode, directly input numeric key and press **[Enter]** key for confirmation to change constant power value.
- Under CW mode, move the cursor with Left/Right Key and press Left/Right Key to adjust value at corresponding position.

#### Operation steps

1. Press **[CW]** key. Press **[Shift] + [CV]** to enter parameter setting screen.

Constant Power

Range=400.00W

2. Set maximum working power value and press **[Enter]** key.

Constant Power

- Range =1.00W
3. Set maximum voltage value and press **[Enter]** key.  
Constant    Power  
High=130.00V
  4. Set minimum voltage value and press **[Enter]** key.  
Constant    Power  
Low=0.000V
  5. Complete parameter setting.  
10.0000V    0.0000A  
0.00W    CW=1.00W



#### NOTE

If the above method is for editing auto test step (as mentioned below), constant power range can also be set.

### 3.3 Input control function

Control input switch of the electronic load by pressing **[On/Off]** key on the front board. If **[On/Off]** lamp is on, the input is on; and if **[On/Off]** lamp is off and the input is off. When the electronic load is on, the VFD working status indicator is OFF.

### 3.4 Keyboard locking function

Press the composite key **[Shift] + 8** to lock the instrument board key, and the VFD displays \*. Under this function status, the setting value cannot be changed and the mode cannot be switched. Press this key again to cancel locking.

### 3.5 Short-circuit analog function

The load can analog a short circuited circuit at input terminal. Under board operation, press the **[Shift] + 1** key to switch short circuit status. The short circuit status does not influence existing setting value. When the **[Shift] + 1** are pressed again, the load returns back to original setting status.

Actual current value consumed by load at short circuit depends on the existing working mode of load and current range. Under CC, CW and CR modes, maximum short-circuit current is 110% of current range. Under CV mode, short circuit current is equivalent to that constant voltage value of load is 0 V.

### 3.6 System menu function (System)

Press **[Shift] + 5** to enter system menu setting (SYSTEM MENU).

|            |                    |  |
|------------|--------------------|--|
| Initialize | INITIALIZE SYSTEM? |  |
|------------|--------------------|--|

|               |                                                                                   |                                                                      |
|---------------|-----------------------------------------------------------------------------------|----------------------------------------------------------------------|
|               | NO                                                                                | Keep existing configurations                                         |
|               | YES                                                                               | Recover all configurations to factory set values                     |
| Power-ON      | POWER-ON PARAMENT                                                                 |                                                                      |
|               | RST(default)                                                                      | Set the input status of load at powering on as "status as delivered" |
|               | SAV0                                                                              | Set the input status of load at powering on as SAVE 0 value          |
| Buzzer        | BUZZER STATE                                                                      | Set the buzzer status                                                |
|               | On (default)                                                                      | Set the buzzer as ON status.                                         |
|               | Off                                                                               | Set the buzzer as OFF status.                                        |
| Knob          | LOAD ON KNOB MODE                                                                 | Set the pulse knob                                                   |
|               | Update(default)                                                                   | Real-time update                                                     |
|               | Old                                                                               | Not update                                                           |
| Trigger       | TRIGGER SOURCE                                                                    | Set triggering mode                                                  |
|               | Manual (Def)                                                                      | Manual trigger                                                       |
|               | External                                                                          | External signal trigger mode                                         |
|               | Hold                                                                              | Trig: IMM valid                                                      |
|               | Bus                                                                               | GPIB bus trigger mode                                                |
|               | Timer                                                                             | Timer trigger mode                                                   |
| Memory        | MEMORY                                                                            | Operated with Recall button to recall 100 groups memories.           |
|               | Group=(0-9)                                                                       | 0: represent group 1-10, 1: represent 11-20, and so on.              |
| Displ         | DISPLAY ON TIMER                                                                  | Screen displays loading time                                         |
|               | On                                                                                | Start function                                                       |
|               | Off (default)                                                                     | Stop function                                                        |
| Communication | COMMUNICATION                                                                     | Select the interface for communication with a computer               |
|               | RS232<br>After interface entry, press the Arrow Key to select RS232 configuration | 4800, 8, N non parity check, 1, NONE                                 |
|               |                                                                                   | 9600 E even parity check CTS/RTS                                     |
|               |                                                                                   | 19200 O odd parity check XON/XOFF                                    |
|               |                                                                                   | 38400                                                                |
|               |                                                                                   | 57600                                                                |
|               |                                                                                   | 115200                                                               |
|               | USBTMC                                                                            |                                                                      |
|               | GPIB                                                                              | Address (0-31)                                                       |
| Protocol      | PROTOCOL                                                                          |                                                                      |
|               | SCPI (Default)                                                                    | SCPI protocol                                                        |
|               | Extend-Table                                                                      | Expand SCPI protocol for compatibility of other machines             |

## 3.7 Configuration menu function (Config)

Press **[Shift] + 6** (Config) keys to enter menu configuration.

|         |                    |                                       |                                       |
|---------|--------------------|---------------------------------------|---------------------------------------|
| Von     | VON LATCH          |                                       | Start judgment voltage of load        |
|         | On                 | Start LATCH function                  |                                       |
|         | Point= 2V          |                                       | Set load voltage                      |
|         | Off                | Stop LATCH function                   |                                       |
|         | Point= 2V          |                                       | Set load voltage                      |
| Protect | PROTECT MENU       |                                       |                                       |
|         | Max-p              | Set hardware power protection         |                                       |
|         | MAX POWER          |                                       |                                       |
|         | Point=149.99W      |                                       | Set hardware protective power value   |
|         | A-Limit            | Set software current protection       |                                       |
|         | CURRENT LIMIT      |                                       |                                       |
|         | On                 | Start function                        |                                       |
|         | Point=30A          |                                       | Set software current protective value |
|         | Delay= 3S          |                                       | Set software current protective delay |
|         | Off                | Stop function                         |                                       |
|         | P- Limit           | Set software power protection         |                                       |
|         | POWER LIMIT        |                                       |                                       |
|         | Point=150W         |                                       | Set software power protective value   |
|         | Delay= 3S          |                                       | Set software power protective delay   |
|         | Time               | Set LOAD ON timer                     |                                       |
|         | ON-TIMER           |                                       |                                       |
|         | On                 | Start function                        |                                       |
|         | Delay=10S          | Set LOAD ON timer value               |                                       |
|         | Off                | Stop function                         |                                       |
| Measure | MEASURE MENU       |                                       |                                       |
|         | V-Range            | Auto switch function of voltage range |                                       |
|         | VOLTAGE AUTO RANGE |                                       |                                       |
|         | On                 |                                       | Start auto voltage range              |
|         | Off                |                                       | Stop auto voltage range               |
|         | TimeV1             | Measure voltage rise/drop time        |                                       |
|         | TIMER VOLTAGE1     |                                       |                                       |
|         | Point=0.000V       |                                       | Set starting voltage value            |
|         | TimeV2             | Measure voltage rise/drop time        |                                       |
|         | TIMER VOLTAGE2     |                                       |                                       |
|         | Point=120.00V      |                                       | Set stop voltage value                |
|         | FILTER             |                                       | Smoothing function                    |

|              |                        |                                                                                   |
|--------------|------------------------|-----------------------------------------------------------------------------------|
|              | Average Count=2^(2~16) | Set of average count                                                              |
| CR-LED       | CR LED MODE            | Analog LED lamp function (under CR mode)                                          |
|              | On                     | Open function (Under CR mode, press <b>[Shift]</b> + <b>[CV]</b> to set Vd value) |
|              | Off                    | Stop function                                                                     |
| Remote-Sense | REMOTE SENSE STATE     | Remote sense compensation measurement                                             |
|              | On                     | Start remote sense compensation function                                          |
|              | Off                    | Stop remote sense compensation function                                           |
| Ext-Program  | EXTNAL PROGRAM         | External analog function                                                          |
|              | On                     | Start external 0-10V analog control function                                      |
|              | Off                    | Stop external 0-10V analog control function                                       |

## 3.8 Triggering function

Triggering function is necessary to operate dynamic pulse output and list output. There are five triggering methods to synchronously trigger the tested instrument.

Optional triggering sources of triggering function of electronic load comprise:

- **Key ([Trig] key) trigger:** when key trigger is valid, press **[Trig]** key and the load will trigger an operation.
- **External trigger signal (TTL):** TRIG on the rear board is the triggering input terminal. When external trigger signal method is effective, after applying a low pulse (> 10 us), the load will trigger an operation.
- **Bus trigger:** when the bus trigger is valid, after the load receives a trigger command (GET or \*TRG) from GPIB port, the load will trigger an operation.
- **Timing trigger:** when the timing trigger is valid, the load will automatically trigger an operation at intervals.
- **Trigger holding:** when trigger holding is valid, only when the load receives trigger command (TRIG: IMM), the load will trigger an operation.

Select the triggering sources as follows:

### Operation steps

1. Press **[Shift]** + **5** (system) to enter system menu setting screen.  
Initialize Power-ON Buzzer
2. Press Left/Right key and move to Trigger. Press **[Enter]** to enter triggering source selection screen.  
Manual (Def) External Hold
3. Press Left/Right key to select trigger method. Press **[Enter]** to complete setting.  
**Manual (Def):** Manual trigger  
**External:** external signal trigger

**Hold:** special command trigger

**Bus:** BUS command trigger

**Timer:** timer trigger

4. Press **[Esc]** to exit setting. The system displays original values under different modes.


## 3.9 Dynamic test function

Through dynamic test operation, the electronic load can be switched between two setting parameters based on setting rules. This function can be used to test dynamic performances of power supply. For dynamic test operation, press **[Tran]** key on the front board to enter the dynamic setting menu. Before test, firstly, set parameters related to dynamic test operation, including dynamic test mode, A value, B value, pulse width time, frequency, duty ratio, etc. Under CC mode, current ascending and descending slopes should be set for dynamic test.

The dynamic test mode can be divided into continuous mode, pulse mode and toggle mode.

### 3.9.1 Continuous mode

Under continuous mode, after enabling dynamic test operation, the load will be switched continuously between A value and B value.



Taking CC mode as example (operations under other modes are similar), when output voltage and current of the tested instrument are 10V and 3A respectively, the load current will switch from 1A and 2A. Set the dynamic test parameters and perform the test as follows:

1. Press **[Tran]** key. Operate Left/Right key. Move to On and press **[Enter]** for confirmation.

TRANSITION

On Off


2. Select Continuous, Press **[Enter]** key (The Trig lamp that indicates VFD screen status is on).

TRANSITION

- Continuous Pulse Toggle
3. Operate Left/Right key and select high rate and low rate. Move to the High-Rate and press **[Enter]** key.  
TRANSITION  
High-Rate Low-Rate
  4. Set ascending slope and press **[Enter]** key.  
TRANSITION  
Rise up=2.000A/uS
  5. Set descending slope and press **[Enter]** key for confirmation.  
TRANSITION  
Rise down=2.000A/uS
  6. Set A value and press **[Enter]** key for confirmation.  
TRANSITION  
Level A=1A
  7. Set B value and press **[Enter]** key for confirmation.  
TRANSITION  
Level B=2A
  8. Set frequency value and press **[Enter]** key for confirmation.  
TRANSITION  
Frequency=50Hz (0.01-25000Hz)
  9. Set duty ratio and press **[Enter]** key for confirmation.  
TRANSITION  
Duty=98% (0.1%-99.9%)
  10. Start dynamic test and operate Left/Right key. Move to On and press **[Enter]** key for confirmation.  
TRANSITION  
On Off
  11. Enter the dynamic test mode.  
10.0000V 0.0000A  
0.00W 0 TRAN
  12. Press **[On/Off]** key and press **[Trig]** key.  
The load will continuously switch between A and B value. Time of operations is shown at bottom right.
  13. Press CC/CV/CR/CW key or any composite function key to exit dynamic test function. Repeat Steps 1-12 to continue parameter setting and operation of dynamic test.

### 3.9.2 Pulse mode

Under pulse mode, after enabling dynamic test operation, the load will switch to A value after receiving of a trigger signal. Then the load will switch back to B value and be constant at B value after maintaining A for pulse width time.



Taking CC mode as example (operations under other modes are similar), when output voltage and current of the tested instrument are 10V and 3A respectively, the load current will switch from 1A and 2A. Set the dynamic test parameters and perform the test as follows:

1. Press **[Tran]** key. Operate Left/Right key. Move to On and press **[Enter]** for confirmation.  
TRANSITION  
On Off
2. Select Pulse, Press **[Enter]** key (The Trig lamp that indicates VFD screen status is on).  
TRANSITION  
Continuous Pulse Toggle
3. Operate Left/Right key and select high rate and low rate. Move to the High-Rate and press **[Enter]** key.  
TRANSITION  
High-Rate Low-Rate
4. Set ascending slope and press **[Enter]** key.  
TRANSITION  
Rise up=2.000A/uS
5. Set descending slope and press **[Enter]** key for confirmation.  
TRANSITION  
Rise down=2.000A/uS
6. Set A value and press **[Enter]** key for confirmation.  
TRANSITION  
Level A=1A
7. Set B value and press **[Enter]** key for confirmation.  
TRANSITION  
Level B=2A
8. Set time width and press **[Enter]** key for confirmation.  
TRANSITION  
Pulse Width=5S (0.00002-3600S)
9. Start dynamic test and operate Left/Right key. Move to On and press **[Enter]** key for confirmation.  
TRANSITION  
On Off
10. Enter the dynamic test mode.


10.0000V 0.0000A

0.00W 0 TRAN

11. Press **[On/Off]** key to open input and press **[Trig]** key (Triggering key)  
The load will switch after receipt of every trigger signal. The load will continuously switch between A and B value. Time of operations is shown at bottom right.
12. Press **CC/CV/CR/CW** key or any composite function key to exit dynamic test function. Repeat Steps 1-11 to continue parameter setting and operation of dynamic test.

### 3.9.3 Toggle mode

Under toggle mode, after enabling dynamic test operation, the load will be switched continuously between A value and B value after receipt of every trigger signal.



Taking CC mode as example (operations under other modes are similar), when output voltage and current of the tested instrument are 10V and 3A respectively, the load current will switch from 1A and 2A. Set the dynamic test parameters and perform the test as follows:

1. Press **[Tran]** key. Operate Left/Right key. Move to On and press **[Enter]** for confirmation.  
TRANSITION  
On Off
2. Select Toggle, Press **[Enter]** key (The Trig lamp that indicates VFD screen status is on).  
TRANSITION  
Continuous Pulse Toggle
3. Operate Left/Right key and select high rate and low rate. Move to the High-Rate and press **[Enter]** key.  
TRANSITION  
High-Rate Low-Rate
4. Set ascending slope and press **[Enter]** key.  
TRANSITION  
Rise up=2.000A/uS
5. Set descending slope and press **[Enter]** key for confirmation.

TRANSITION

Rise down=2.000A/uS

6. Set A value and press **[Enter]** key for confirmation.

TRANSITION

Level A=1A

7. Set B value and press **[Enter]** key for confirmation.

TRANSITION

Level B=2A

8. Start dynamic test and operate Left/Right key. Move to On and press **[Enter]** key for confirmation.

TRANSITION

On Off

9. Enter the dynamic test mode.

10.0000V 0.0000A

0.00W 0 TRAN

10. Press **[On/Off]** key to open input and press **[Trig]** key (Triggering key).

The load will switch after receipt of every trigger signal. The load will switch between A and B value for one time. Time of operations is shown at bottom right.

11. Press CC/CV/CR/CW key or any composite function key to exit dynamic test function. Repeat Steps 1-10 to continue parameter setting and operation of dynamic test.

## 3.10 OCP test function

The IT8800 series electronic load is provided with over-current protection test function (OCP). Under OCP test mode, when input voltage reached Von value, delay for a while for the electronic load to latch. Ascend value by step value at regular interval. At the same time, check the load input voltage and judge whether it is higher than standard voltage value. If higher, it indicates that OCP does not occur. Repeat current stepping operation till the load operates to the cutoff current; if lower, it indicates that OCP does occur. Check whether the existing current value is within target scope again. If yes, PASS the test.

Press **[Shift] + [CC]** (OCP) keys to enter OCP test function setting screen.

|          |        |                           |                                 |
|----------|--------|---------------------------|---------------------------------|
| OCP TEST | Run    | OCP TEST                  |                                 |
|          |        |                           | Operate OCP test documents      |
|          | Recall | OCP TEST                  |                                 |
|          |        | Recall OCP File=1         | Recall OCP test documents (1-5) |
|          | Edit   | OCP TEST                  |                                 |
|          |        | 1:Voltage on level=0.000V | Set Von voltage value           |
|          |        | 2:Voltage on Delay=0.00S  | Set Von voltage delay time      |
|          |        | 3:Current Range=0.000A    | Set working current range       |
|          |        | 4:Start Current=0.000A    | Set initial current value       |
|          |        | 5:Step Current=0.000A     | Set step current value          |
|          |        | 6:Step Delay=0.00S        | Set step delay time             |
|          |        | 7:End Current=0.000A      | Set cutoff current value        |

|  |  |                            |                                        |
|--|--|----------------------------|----------------------------------------|
|  |  | 8:OCP Voltage=0.000V       | Set OCP value                          |
|  |  | 9:Max Trip Current=0.000A  | Set over-current range (maximum value) |
|  |  | 10:Min Trip Current=0.000A | Set over-current range (minimum value) |
|  |  | Save OCP File=1 (1-5)      | Save OCP test documents                |

Operating steps:

1. Press **[Trig]** key to start OCP test. If within range, PASS the test and the board will display as follows:

|                        |         |
|------------------------|---------|
| 9.9973V                | 0.0005A |
| 0.01W 5.100A PASS STOP |         |

If not, there is FAULT and the board will display as follows:

|                         |         |
|-------------------------|---------|
| 9.9973V                 | 0.0005A |
| 0.01W 5.100A FAULT STOP |         |

2. End test. The User should return back to setting screen for resetting.



NOTE

If the set OCP voltage value is higher than the power voltage value, the OCP will fail to operate and the board will display as follows:

|                         |         |
|-------------------------|---------|
| 9.9990V                 | 0.0009A |
| 0.01W 0.100A FAULT STOP |         |

## 3.11 OPP test function

The IT8800 series electronic load is provided with overpower protection test function (OPP). Under OPP test mode, when input voltage reached Von value, delay for a while for the electronic load to latch. Ascend value by step value at regular interval. At the same time, check the load input voltage and judge whether it is higher than standard voltage value. If higher, it indicates that OPP does not occur. Repeat power stepping operation till the load operates to the cutoff power; if lower, it indicates that OPP does occur. Check whether the existing power value is within target scope again. If yes, PASS the test.

Press **[Shift] + [CW]** (OPP) keys to enter OPP test function setting screen.

|          |        |                   |                                 |
|----------|--------|-------------------|---------------------------------|
| OPP TEST | Run    | OPP TEST          |                                 |
|          |        |                   | Operate OPP test documents      |
|          | Recall | OPP TEST          |                                 |
|          |        | Recall OPP File=1 | Recall OPP test documents (1-5) |
|          | Edit   | OPP TEST          |                                 |

|  |                           |                                     |
|--|---------------------------|-------------------------------------|
|  | 1:Voltage on level=0.000V | Set Von voltage value               |
|  | 2:Voltage on Delay=0.00S  | Set Von voltage delay time          |
|  | 3:Current Range=0.000A    | Set working current range           |
|  | 4:Start Power=0.000W      | Set initial power value             |
|  | 5:Step Power=0.000W       | Set step power value                |
|  | 6:Step Delay=0.00S        | Set step delay time                 |
|  | 7:End Power=0.000W        | Set cutoff power value              |
|  | 8:OPP Voltage=0.000V      | Set OPP value                       |
|  | 9:Max Trip Power =0.000W  | Set overpower range (maximum value) |
|  | 10:Min Trip Power =0.000W | Set overpower range (minimum value) |
|  | Save OPP File=1 (1-5)     | Save OPP test documents             |

Operating steps:

1. Press **[Trig]** key to start OPP test. If within range, PASS the test and the board will display as follows:

|        |                  |
|--------|------------------|
| 9.996V | 0.0007A          |
| 0.01W  | 49.10W PASS STOP |

If not, there is FAULT and the board will display as follows:

|        |                  |
|--------|------------------|
| 9.996V | 0.0007A          |
| 0.01W  | 48.6W FAULT STOP |

2. End test. The User should return back to setting screen for resetting.



NOTE

If the set OPP voltage value is higher than the power voltage value, the OPP will fail to operate and the board will display as follows:

|        |                 |
|--------|-----------------|
| 9.996V | 0.0007A         |
| 0.01W  | 0.1W FAULT STOP |

## 3.12 Battery discharge test function

In the IT8800 series electronic load, constant current mode is applied for capacity test with programmatic setting of cutoff level/capacity/discharging time. Whenever met any condition, it will automatically stop test. If cutoff level is set as the stop condition, the system determines whether the battery is about to reach the set threshold value or unsafe status when the battery voltage is low, and if yes, an automatic stop will be activated.

During the test, the voltage, time and discharged capacity of the battery can be observed. Battery discharge test is a necessary step before battery

replacement for it can reflect reliability and remaining life of battery.

Enter **[Shift] + 3** to enter function testing screen of battery discharge test.

|                   |            |                 |                             |
|-------------------|------------|-----------------|-----------------------------|
| STOP<br>CONDITION | Voltage    | STOP Condition  |                             |
|                   |            | Stop Voltage    | Set cutoff voltage          |
|                   | Capability | STOP Condition  |                             |
|                   |            | Stop Capability | Set battery cutoff capacity |
|                   | Timer      | STOP Condition  |                             |
|                   |            | Stop Timer      | Set discharge time          |


### Operation method:

1. Press **[On/Off]** key to cut off load input status. Connect the battery to be tested. Under CC mode, press **[Shift] + 3** keys to enter battery discharge function menu.
2. Set discharge stopping conditions:
  - Type I: Press **[Shift] + 3** keys and select Capability. Press **[Enter]** key and the VFD displays Cutoff Capability =Ah(0~999.999Ah). Set battery stop capacity. Press **[Enter]** key for confirmation. When set battery capacity is reached, the load input status will automatically be OFF.
  - Type II: Press **[Shift] + 3** keys and select Voltage. Press **[Enter]** key and the VFD displays Stop Voltage=V. Set cutoff voltage and press **[Enter]** key. When the battery voltage drops to cutoff voltage, the load input status will automatically be OFF.
  - Type III: Press **[Shift] + 3** key and select Timer. Press **[Enter]** key and the VFD displays Stop Timer=S(0~99999S). Set discharge time and press **[Enter]** key. When the set stop time is reached, the load input status will automatically be OFF.
3. Press **[Trig]** key to start testing. The board will display discharge voltage, current discharge time and capacity (AH).
4. Press **[Esc]** key to exit battery capacity test mode.

## 3.13 CR-LED test function

With adding of diode break-over voltage setting in the IT8800 series electronic load under conventional CR mode, the electronic load only works when voltage applied at its both ends is higher than the diode break-over voltage to give a real simulation of diode working principle, i.e., the ripple current at real LED test.

The I-V curve of LED is as shown below. Under conventional CR mode, the electronic load only simulates the static working point of diode as shown in the red circle of the following figure. It is unable to verify the dynamic characteristics of LED under normal working conditions, and the status of accurate ripple current.



## Setting CR-LED Mode

**Example:** LED driver specification

The output current is 200mA and the range of output voltage is from 45V to 62V.

Operating steps:

1. **Start CR-LED function.**
  - 1) Press **[Shift] + 6** keys to enter configuration menu.
  - 2) Press Right Key and select "CR-LED". Press **[Enter]** key for entry. Select "on" and press **[Enter]** key.
  - 3) Press **[Esc]** key to exit.
2. **Set CR mode and Vd value**

For example, the output voltage of LED driver is 50V, verify that whether the output current of LED is rated current 200mA.


  - 1) Press **[CR]** key and set corresponding constant resistance. (Set CR=50Ω)
  - 2) Press **[Shift] + [CV]** keys for a series of related setting: range=7500.0, high=130V, low=0V, which may remain the original values. Vd will be set based on the calculation below. (Set Vd=40V)
  - 3) Press the **[Enter]** key to save the settings.
3. **Press [On/Off] key to turn on load input.**

Calculation method of Vd and R:

Definition:

- Vo: constant working voltage of load LED of LED constant current source;
- Io: output current of LED constant current source;
- Vd: break-over voltage of diode (string);
- R: constant resistance.

V-I curve of LED is as shown below.



According to four parameters above and the V-I curve of LED, you can calculate the value of R and Vd.

$$R = \frac{V_2 - V_1}{I_2 - I_1}$$

$$V_d = V_o - (I_o \times R)$$



NOTE

The value of V2, V1, I2 and I1 should be close to the static working point of LED as shown in the red circle above.

Or you can roughly calculate the value of R and Vd with the following equation.

$$V_d = V \times 0.8 \quad R = 0.2V/I$$

Where:

- V: constant working voltage of load LED of LED constant current source;
- I: output current of LED constant current source;
- Vd: break-over voltage of diode (string);
- R: constant resistance.

In the example:  $V_d = 50V \times 0.8 = 40V$      $R = (0.2 \times 50V) / 0.2A = 50\Omega$ .

### 3.14 Measurement of voltage rise time

The IT8800 series electronic load is provided with special voltage rise/drop time measurement function. This function gives a simple analog of voltage rise/drop speed of oscilloscope test power.

Operation methods:

#### Set initial voltage and final voltage

1. Press **[Shift] + 6** keys to enter configuration menu. Press Right key. Select "Measure" and press **[Enter]** key.
2. Press Left/Right Key to select "TimeV1". Press **[Enter]** key. Press numeric keys to set initial voltage value and press **[Enter]** key.
3. Press Left/Right Key to select "TimeV2". Press **[Enter]** key. Press numeric

keys to set final voltage value and press **[Enter]** key.

4. Press **[Esc]** to exit setting.

#### Start timer function

5. Press **[Shift] + 5** keys to enter system menu. Press Right key till "Displ" flicks and press **[Enter]** key.
6. Press Left/Right Key to select "On". Start timer function and press **[Enter]** key.
7. Press **[Esc]** to exit setting.
8. VFD second line will display time 0.0000S between power value and set value.

|                                                              |
|--------------------------------------------------------------|
| OFF CC<br><br>0.0001V 0.0002A<br><br>0.00W 0.0000S CC=0.000A |
|--------------------------------------------------------------|

#### Measurement of rise time

9. Connect DC power to be tested to the input terminal of the electronic load. The power is set with a value that is higher than the set final voltage value. Keep power output in OFF status.
10. Set a constant current value on the load and open the load input.
11. Open power output.
12. The electronic load timer starts timing. After ending, time will keep stable, which is rise time of voltage.
13. Close the power output. The electronic load VFD will display voltage drop time.

## 3.15 Configuration save function

The electronic load can save some commonly-used parameters in 100-group (0-99) NVM for convenient and fast usage. Saving parameters comprise working mode, voltage, current, etc. The Save key can be used for saving parameters. The RECALL key is for quick invoking.

### Operation steps

If the operator needs to save configured parameter values for direct recall in follow-up operation, refer to the steps below:

e.g., power supply 6V and 3A. The electronic load works under constant current (CC) 1A. Save "CC 1A" in register 9 for recall.

#### ● SAVE

1. Set parameters and press **[Shift] + 4** (Save) to save data. Press **9** key (to select in which group the data is to be saved).

|         |          |
|---------|----------|
| 5.8949V | 0.99994A |
| 5.89W   | SAVE 9   |

2. Press **[Enter]** key for confirmation.

|         |           |
|---------|-----------|
| 5.8949V | 0.99994A  |
| 5.89W   | cc=1.000A |

- **RECALL**

1. Press **[Recall]** key and press **9** (to select from which group the data is recalled).  
5.8949V      0.99994A  
5.89W      cc=1.000A

## Memory function

When you want to recall the data saved in the memory, you should set memory group in the system menu first.

Group 0 means you can recall data saved in 0-10 groups. Group 1 means you can recall data saved in 11-20 groups. Group2-Group 9 can be concluded in the same manner.

## 3.16 VON function

When testing some power products with slow voltage rise speed, if the electronic load input is opened before power, the power may latch protection. In this way, the user may set VON value. The electronic load only latches when power voltage is higher than this value.

Press **[Shift]+ 6** keys to enter configuration menu. Set voltage value in Voltage on under configuration menu to control on/off status of electronic load. When VON LATCH function is started, it indicates that Von Point latches load status.




### NOTE

Please confirm whether it is necessary to set loading voltage, a step that provides convenience for limiting working voltage value. If not necessary, do not set the loading voltage without authorization to prevent unnecessary trouble from failure of loading.

If the instrument cannot load, please firstly check whether the VON function is set. If yes, reset the Von value to minimum value (which may be directly set as 0. If minimum voltage value of instrument is not 0, press 0 for confirmation and the menu will automatically set the value as minimum value).

This function is invalid under CV mode.

When VON LATCH function is started, the load starts load test only when the power voltage rises and is higher than Von Point loading voltage. When the power voltage drops and is lower than Von Point unloading voltage, the load will not unload.



Load working range when VON LATCH is started

## 3.17. Protective function

The load is provided with following protective functions: overvoltage protection (OVP), over-current protection (OCP), over-power protection (OPP) and over-temperature protection (OTP).

If any one of the above protections is enabled, the load will have corresponding actions. Press any key on the front board to reset protection functions. For example, in case of over-temperature protection, the load will give alarm and the input will automatically switch to OFF status. The load VFD will display OTP.

### 3.17.1 Over-voltage protection (OVP)

The load will be immediately OFF and the buzzer will sound if the overvoltage circuit is triggered. OV and VF bits of the status register will be set and OVP will be displayed on the screen of the load till resetting. In case of overvoltage protection, the VF pin of the 8-pin connector on rear board of the load outputs TTL high level and the VF pin can be used for controlling output status of the power to be tested.

#### Clear overvoltage protection status:

Inspect whether voltage of object under test is within load rated voltage or set protection voltage range. If not, disconnect the object. Press any key on front board (or send command to PROtection:CLEAr), the load front board (OVP) word will get cleared and the load will exit OVP protection status.

### 3.17.2 Over-current protection (OCP)

The electronic load is provided with two kinds of over-current protections:

hardware over-current protection and software over-current protection.

- Hardware over-current protection: maximum load current of the electronic load is limited within about 110% of the existing current range by hardware. When the hardware triggers over-current protection, OC bit of the status register will be set; when such protection is removed, the OC bit will be reset. The existing On/Off status of load will not be changed by the hardware over-current protection.
- Software over-current protection: the user can set load software over-current protection value following steps: press **[Shift]+ 6** key >Protect> A-limit (set as ON). A point is set as OCP current value and A delay set as pre-alarm delay time. When software over-current protection function is on, if the loading current value exceeds delay of such over-current protection set value, the load will automatically be OFF and the VFD will display OCP. At the same time, OC and PS bits of the status register will be set and keep till reset.

**Clear over-current protection status:**

Inspect whether current of object under test is within load rated current or set protection current range. If not, disconnect the object. Press any key on front board (or send command to PROtection:CLEar), the load front board (OCP) word will get cleared and the load will exit OCP protection status.

### 3.17.3 Over-power protection (OPP)

The electronic load is provided with two kinds of overpower protections: hardware over-power protection and software overpower protection.

- Hardware over-power protection: the user can set load hardware overpower protection. Load overpower will be limited to existing power value. The existing On/Off status of load will not be changed by the hardware overpower protection.
- Software overpower protection: the user can set load software overpower protection value following steps: **[Shift] + 6** >Protect>Point Set power value. P-limit is set as pre-alarm delay time. If the loading power value exceeds delay of such overpower protection set value, the load will automatically be OFF and the VFD will display OPP. At the same time, OP and PS bits of the status register will be set and keep till reset.

**Clear overpower protection status**

Inspect whether power of object under test is within load rated power or set protection power range. If not, disconnect the object. Press any key on load front board (or send command to PROtection:CLEar), the load front board (OPP) word will get cleared and the load will exit OPP protection status.

### 3.17.4 Over-temperature protection (OTP)

When internal power device of load is higher than about 85 °C, the load is under temperature protection. At this time, the load will automatically be OFF and VFD will display OTP. At the same time, OT and PS bits of the status

register will be set and keep till reset.

#### Clear over-temperature protection


When load temperature is decreased to protection point, press any key on front board (or send command to PROtection:CLEAr), the load front board (OTP) word will get cleared and the load will exit OTP protection status.

## 3.18 List operation (LIST)

LIST mode provides an accurate, fast and low-cost way to complete any complicated current change mode, which enables synchronization of internal or external signals in multiple quasi-bit load precision tests.

When different trigger sources are selected, the LIST function will form a variety of complex sequences by editing step value, pulse width and slope of each step to meet complicated test requirements. LIST parameters comprise designation of input list file, input step count (2-84 steps at maximum), step time (0.00002 s – 3600 s) as well as setting value and slope of each step. The list file can be stored in non-volatile RAM available for a quick output in case of usage. The user can edit 7 groups of list files at maximum.

If the load operation mode is at List operation, the load will start List operation, when it receives a trigger signal till completion or receipt of another trigger signal. Before List operation, be sure to edit List operation files and save them in load non-volatile RAM. Refer to examples below to know how to execute List operation through board. It is assumed that output voltage and current of the tested instrument are 10V and 3A respectively and the load is under CC mode.



Edit the LIST file and trigger to operate this file. Operation steps:

### Operation steps

- Press **[List]** key. Operate Left/Right key. Move to Edit and press **[Enter]** key.  
LIST  
On Recall Edit
- Operate Left/Right key and move to the High-Rate and press **[Enter]** key.  
EDIT LIST  
High-Rate Low-Rate
- Set CC range and press **[Enter]** key.

- EDIT LIST
- Current Range=3A
4. Edit number of steps. Press **2** key to edit two steps. Press **[Enter]** key for confirmation.  
EDIT LIST  
File Step=2 (2-84)
  5. Edit current value in step 1And press **[Enter]** key for confirmation.  
EDIT LIST  
Step 001 Level=1A
  6. Edit slope in step 1And press **[Enter]** key for confirmation.  
EDIT LIST  
Step 001 Rate=0.1A/uS
  7. Edit time in step 1And press **[Enter]** key for confirmation.  
EDIT LIST  
Step 001 Width=5S
  8. Edit current value in step 2And press **[Enter]** key for confirmation.  
EDIT LIST  
Step 002 Level=2A
  9. Edit slope in step 2And press **[Enter]** key for confirmation.  
EDIT LIST  
Step 002 Rate=0.1A/uS
  10. Edit time in step 2And press **[Enter]** key for confirmation.  
EDIT LIST  
Step 002 Width=5S
  11. Edit repeat count and press **[Enter]** key for confirmation.  
EDIT LIST  
Repeat Count=3 (1-65535)
  12. Save all edited files and press **[Enter]** key for confirmation.  
EDIT LIST  
Save List File=1 (1-9)
  13. Operate Left/Right key and move to On. Press **[Enter]** key (The Trig lamp that indicates VFD screen status is on). Press **[Esc]** key to exit setting.  
LIST  
On Recall Edit  
List operation running
  15. Press CC/CV/CR/CW key or any composite function key to exit List test function.

For direct recall of existing List files and triggering of List operation, refer to steps below:


## Operation steps

1. Press **[List]** key and ensure that ON lamp flicks. If not, press **[Enter]** before operating Left/Right key. Move to **[Recall]** and press **[Enter]** key.  
LIST

- On      Recall      Edit
- Select edited files and press **[Enter]** for confirmation.  
Recall List File=1
  - Operate Left/Right key and move to On. Press **[Enter]** key (The Trig lamp that indicates VFD screen status is on). Press **[Esc]** key to exit setting.  
LIST
  - On      Recall      Edit
  - Press **[On/Off]** key to open input and press **[Trig]** key (Triggering key)  
List operation running.

## 3.19 Terminal function of rear board

Terminals on IT8800 rear board comprise remote sensor terminal, external trigger terminal, external analog control terminal, voltage fault indication terminal, external On/Off control terminal and current monitoring terminal. Terminal schematic (as shown below):



| Pin                | Pin function                                         |
|--------------------|------------------------------------------------------|
| Sense+, Sense-     | Remote sense terminal                                |
| EXT PRG+, EXT PRG- | External analog control terminal                     |
| ⏏                  | Negative input terminal for TRIG, ON and VF          |
| TRIG               | Positive input terminal for trigger                  |
| ON                 | Positive input terminal for external On/Off control  |
| VF                 | Positive input terminal for voltage fault indication |

### 3.19.1 Remote sense compensation functions

Under CC, CV, CR or CW mode, if the load consumes large current, a large voltage drop will be detected in connection line between tested instrument and load terminal. To ensure measurement accuracy, a remote sense measurement terminal is provided at load rear board to compensate voltage drop lost in wire.


**Remote sense operation:** **SENSE (+)** and **SENSE (-)** are remote input terminals. To avoid voltage drop caused by long input wire of load, the remote sense allows direct measurement at input terminal source so as to improve measurement accuracy.

Before using the remote sense measurement function, the user must set the load in remote sense measurement mode.

Setting procedures:

Press **[Shift] + 6** to enter menu. Move Left/Right key and select Remote-Sense. Press **[Enter]** key and select ON to start Sense function.

### Wiring Diagram of Remote Sense



### 3.19.2 External trigger operation

When rear board triggering mode is selected, firstly, set the trigger source as External and the triggering signal is input from the rear board TRIG terminal.

Set the triggering sources as follows:

Press **[Shift]+ 5** keys to enter system menu. Click Right key till Trigger appears

and flicks. Press **[Enter]** to entry and press ◀ ▶ to select External. Press

**[Enter]** for confirmation. Press **[Esc]** to exit the menu.

When external trigger is selected, the positive and negative TRIG terminals will generate trigger signal and the low pulse is valid.

Input corresponding to one trigger can be used for triggering dynamic test, LIST test and auto test.

### 3.19.3 External analog test

Loading voltage or current of the electronic load can be controlled by EXT PRG (positive and negative) analog terminals on rear board. Connect 0-10V adjustable voltage at the EXT PRG terminal to analog input from 0- full range so as to adjust input voltage and current of load (10V corresponds to voltage or current of load at full range).

### 3.19.4 External On/Off Control

The load input switches can be controlled by the external TTL electrical level. During external input control, the **on/off** key will become invalid and the load input switches can only be controlled by the external TTL electrical level. The load input will be switched on in case of low level external input; and the load input will be switched off in case of high level external input.

### 3.19.5 Voltage fault indication terminal

When load is under overvoltage protection or terminal reverse polarity protection, VF pin voltage fault indication terminal outputs high level.


### 3.19.6 Current monitoring (I Monitor)

The 0-10V analog output signal of current monitoring output terminal represents input current to which the terminal belongs from 0 to full range. An external voltmeter or oscilloscope can be connected to display input current change.

## 3.20 External Signal Control Interface

### Pins Introduction

Besides the RS232 communication interface, the rear panel is also equipped with a DB-9 COM interface, which is the external signal control interface used in auto test. The pin definitions are as follows.



| Base pin number | Description                                   |
|-----------------|-----------------------------------------------|
| 1               | The auto test runs last step.                 |
| 2               | The auto test starts to run.                  |
| 3               | During the auto test, the input is turned on. |
| 4               | Output the failure signal of the auto test.   |
| 5               | GND                                           |
| 6               | The auto test runs next step.                 |
| 7               | The auto test pauses.                         |
| 8               | The auto test outputs via signal.             |
| 9               | The warning tone signal of auto test outputs. |

You can control the auto test process and test results by transmitting input/output signals through external signal control interface. Different pins of the interface control different functions. Detailed instructions are listed on the above table.

Under external analog control mode, you can switch CC mode through pin 1 of the interface and switch CV mode through pin 6.

### Signal definition

External Signal Control Interface functions involve input and output levels. The input signal is the control signal provided externally to IT8800, the output signal is the level signal provided externally by IT8800.

|              |                   |             |
|--------------|-------------------|-------------|
| Input signal | High level signal | Typical: 5V |
|--------------|-------------------|-------------|

|                           |                   |                     |
|---------------------------|-------------------|---------------------|
| (Descending edge trigger) |                   | Range: 2.5V-10V     |
|                           |                   | Current: <1mA       |
|                           | Low level signal  | Typical: 0V         |
|                           |                   | Range: 0V-0.7V      |
| Output signal             | High level signal | Current: <1mA       |
|                           |                   | Voltage level: 3.3V |
|                           | Low level signal  | Current: <5mA       |
|                           |                   | suspended           |

## 3.21 Auto test function

The IT8800 series electronic load delivers strong auto test functions, which can analog several tests. A total of 10 groups of test files can be edited, and each group test file has 10 steps. Therefore, a maximum of 100 steps can be edited and saved in EEPROM (address).

Edit test files following the steps below:



### NOTE

In the following editing procedures, “Y” indicates selected status. To cancel selected status, press numeric key of corresponding step again.

### Operation steps

- Press **[Shift] + 2** (Program).  
PROGRAM  
Run Recall Edit
- Operate Left/Right key and move to Edit. Press **[Enter]** key to enter editing test files.  
EDIT PROGRAM  
Active Sequence=0987654321
- Press numeric key to select required testing steps. The Active Sequence =09876543YY indicates that 1/2 steps have been selected. Press **[Enter]** key for confirmation.  
EDIT PROGRAM  
Active Sequence=09876543YY
- Select whether pause is necessary for these two steps. If step 2 is to be paused, press **2** key. If not, directly press **[Enter]** key for confirmation.  
EDIT PROGRAM  
Pause Sequence=□□□□□□□Y1
- Select whether short-circuit test is necessary for these two steps. If step 1 is to be tested, press **1** key. If not, directly press **[Enter]** key for confirmation.  
EDIT PROGRAM  
Short Sequence=□□□□□□□2Y
- Set loading time of step 1. If 2S is required, directly press **2** key on the

board. Press **[Enter]** key for confirmation.

EDIT PROGRAM

SEQ01 On Time=2S

7. Set unloading time of step 1. If 2S is required, directly press **2** key. Press **[Enter]** key for confirmation.

EDIT PROGRAM

SEQ01 Off Time=2S

8. Set test delay time of step 1. If 1S is required, directly press **1** key. Press **[Enter]** key for confirmation. Tpf is delay time before measurement.

EDIT PROGRAM

SEQ01 P/F Delay Time=1S

9. Set loading time of step 2. If 2S is required, directly press **2** key on the board. Press **[Enter]** key.

EDIT PROGRAM

SEQ02 On Time=2S

10. Set unloading time of step 2. If 2S is required, directly press **2** key. Press **[Enter]** key.


EDIT PROGRAM

SEQ02 Off Time=2S

11. Set test delay time of step 2. If 1S is required, directly press **1** key. Press **[Enter]** key. Tpf is delay time before measurement.

EDIT PROGRAM

SEQ02 P/F Delay Time=1S



Tpf is delay time before measurement.

12. Set conditions for stop test. COMPLETE means to stop after all tests are completed and FAILURE means to stop in case of test error. Press **[Enter]** key for confirmation.

PROGRAM

Complete-Stop Failure-Stop

13. Determine whether to link to next group of test file. If it is to link to second group, press **2**. 0 means not to link to other test files. Press **[Enter]** key for

confirmation.

PROGRAM

Chain Program File=0 (0-10)

#### □ Correspondence Table of Auto Test Files and Step Parameter Saving

|                     |    |    |    |    |    |    |    |    |    |     |
|---------------------|----|----|----|----|----|----|----|----|----|-----|
| Program 1 Sequence  | 1  | 2  | 3  | 4  | 5  | 6  | 7  | 8  | 9  | 10  |
| Save Group          | 1  | 2  | 3  | 4  | 5  | 6  | 7  | 8  | 9  | 10  |
| Program 2 Sequence  | 1  | 2  | 3  | 4  | 5  | 6  | 7  | 8  | 9  | 10  |
| Save Group          | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20  |
| :                   |    |    |    |    |    |    |    |    |    |     |
| :                   |    |    |    |    |    |    |    |    |    |     |
| Program 10 Sequence | 1  | 2  | 3  | 4  | 5  | 6  | 7  | 8  | 9  | 10  |
| Save Group          | 91 | 92 | 93 | 94 | 95 | 96 | 97 | 98 | 99 | 100 |

14. Save the programmed files in EEPROM. A total of 10 groups of files can be saved. If it is to save edited files in group 1, press **1** key. Press **[Enter]** key for confirmation.

PROGRAM

Save Program File=1 (1-10)

15. Press ESC key to exit editing menu.

**The above steps only set entire framework of auto tests. Additional setting is required for specific parameters in each step. This design will facilitate modification of parameters in a single step.**

16. Select required working mode. Set working voltage/current/power/resistance. Press **[Shift] + [CV]** to enter parameter setting.

10.0000V    0.0000A

0.00W        CC=1.000A

17. It is assumed that step 1 edits CC mode as follows: current: 2A, maximum voltage value: 10V, and minimum voltage value: 2V; and step 2 edits CV mode as follows: voltage: 3V, maximum current value: 5A, and minimum current value: 0A. After parameter setting in each step, press **[Esc]** to exit menu setting. And press **[Shift] + 4** for saving. Setting at each step should be saved. The saving position is same as that of step number. **Settings at each step should be independently saved. Refer to the "Correspondence Table for Auto Test Files and Single-Step Parameter Saving Positions".**

18. It is necessary to recall test files for running after editing auto test files.

### Recall test file for running

To recall edited test files from EEPROM quickly after re-energizing instrument, refer to the method below.

1. Press **[Shift] + 2**.

PROGRAM

Run            Recall            Edit

2. Move Left/Right Key and select **[Recall]** key. Press **[Enter]** key for confirmation.

RECALL PROGRAM

Recall Program File=1

3. Move Left/Right Key and select Run. Press **[Enter]** key for confirmation.

PROGRAM

Run            Recall            Edit

4. Display auto test file 1.

PRG01 STOP

5. Press **[Trig]** key.

Operate auto test file 1. Press **[Pause]** key on board to pause auto test.  
Press Move key for next step.

## Chapter4 Technical Specifications

### 4.1 Major technical parameters

| Model                        |                        | IT8813               |               | IT8813B              |               |
|------------------------------|------------------------|----------------------|---------------|----------------------|---------------|
| Rated value<br>( 0~40 °C)    | Input voltage          | 0~120V               |               | 0~500V               |               |
|                              | Input current          | 0~6A                 | 0~60A         | 0~3A                 | 0~30A         |
|                              | Input power            | 750W                 |               | 750W                 |               |
|                              | Min. operating voltage | 0.1V/6A              | 1.0V/60A      | 0.36V3A              | 3.6V/30A      |
| Constant voltage mode        | Range                  | 0.1~18V              | 0.1~120V      | 0.1~50V              | 0.1~500V      |
|                              | Resolution             | 1mV                  | 10mV          | 1mV                  | 10mV          |
|                              | Accuracy               | ±(0.025%+0.05%FS)    |               |                      |               |
| Constant current mode        | Range                  | 0~6A                 | 0~60A         | 0~3A                 | 0~30A         |
|                              | Resolution             | 0.1mA                | 1mA           | 0.1mA                | 1mA           |
|                              | Accuracy               | ±(0.05%+0.05%FS)     |               |                      |               |
| Constant resistance mode *1  | Range                  | 0.02Ω~10Ω            | 10Ω~7.5KΩ     | 0.15Ω~10Ω            | 10Ω~7.5KΩ     |
|                              | Resolution             | 16bit                |               | 16bit                |               |
|                              | Accuracy               | 0.01%+0.08S *2       | 0.01%+0.0008S | 0.01%+0.08S *2       | 0.01%+0.0008S |
| Constant power Mode *3       | Range                  | 750W                 |               | 750W                 |               |
|                              | Resolution             | 10mW                 |               | 10mW                 |               |
|                              | Accuracy               | 0.2%+0.2%FS          |               | 0.2%+0.2%FS          |               |
| Dynamic mode                 |                        |                      |               |                      |               |
| CC mode                      |                        |                      |               |                      |               |
| T1&T2                        |                        | 20uS~3600S /Res:1 uS |               | 20uS~3600S /Res:1 uS |               |
| Accuracy                     |                        | 5uS±100ppm           |               | 5uS±100ppm           |               |
| Ascending/descending slope*4 |                        | 0.0001~0.25A/uS      | 0.001~2.5A/uS | 0.0001~0.1A/uS       | 0.001~1A/uS   |
| Minimum rise time *5         |                        | ≧ 20uS               | ≧ 20uS        | ≧ 20uS               | ≧ 20uS        |
| Measuring range              |                        |                      |               |                      |               |
| Read-back voltage            | Range                  | 0~18V                | 0~120V        | 0~50V                | 0~500V        |
|                              | Resolution             | 1 mV                 | 10 mV         | 1 mV                 | 10 mV         |
|                              | Accuracy               | ±(0.025%+0.025%FS)   |               |                      |               |
| Read-back current            | Range                  | 0~6A                 | 0~60A         | 0~3A                 | 0~30A         |
|                              | Resolution             | 0.1mA                | 1mA           | 0.1mA                | 1mA           |
|                              | Accuracy               | ±(0.05%+0.05%FS)     |               | ±(0.05%+0.05%FS)     |               |
| Read-back power              | Range                  | 750W                 |               | 750W                 |               |
|                              | Resolution             | 10mW                 |               | 10mW                 |               |
|                              | Accuracy               | ±(0.2%+0.2%FS)       |               | ±(0.2%+0.2%FS)       |               |
| Protection range             |                        |                      |               |                      |               |
| Overpower protection         |                        | ≧ 760W               |               | ≧ 760W               |               |

|                            |                      |        |        |          |          |
|----------------------------|----------------------|--------|--------|----------|----------|
| Overcurrent protection     |                      | ≒ 6.6A | ≒ 66A  | ≒ 3.3A   | ≒ 33A    |
| Overvoltage protection     |                      | ≒ 130V |        | ≒ 530V   |          |
| Overtemperature protection |                      | ≒ 85℃  |        | ≒ 85℃    |          |
| Specification              |                      |        |        |          |          |
| Short circuit              | Current (CC)         | ≒ 6.6A | 66A    | ≒ 3.3/3A | ≒ 33/30A |
|                            | Voltage (CV)         | 0V     | 0V     | 0V       | 0V       |
|                            | Resistance (CR)      | ≒ 15mΩ | ≒ 15mΩ | ≒ 120mΩ  | ≒ 120mΩ  |
| Input terminal impedance   | 300KΩ                |        |        | 1MΩ      |          |
| Dimension                  | W439*H133.3*D580（mm） |        |        |          |          |
| Weight                     | 27.5Kg               |        |        | 28.5Kg   |          |

| Model                          |                        | IT8813C              |                    |
|--------------------------------|------------------------|----------------------|--------------------|
| Rated value<br>( 0-40 °C)      | Input voltage          | 0~120V               |                    |
|                                | Input current          | 0~12A                | 0~120A             |
|                                | Input power            | 750W                 |                    |
|                                | Min. operating voltage | 0.12V/12A            | 1.2V/120A          |
| Constant voltage mode          | Range                  | 0.1~18V              | 0.1~120V           |
|                                | Resolution             | 1mV                  | 10mV               |
|                                | Accuracy               | ±(0.025%+0.05%FS)    | ±(0.025%+0.05%FS)  |
| Constant current mode          | Range                  | 0~12A                | 0~120A             |
|                                | Resolution             | 1mA                  | 10mA               |
|                                | Accuracy               | ±(0.05%+0.1%FS)      | ±(0.05%+0.1%FS)    |
| Constant resistance mode<br>*1 | Range                  | 0.02Ω~10Ω            | 10Ω~7.5KΩ          |
|                                | Resolution             | 16 bit               |                    |
|                                | Accuracy               | 0.01%+0.08S   *2     | 0.01%+0.0008S      |
| Constant power Mode *3         | Range                  | 750W                 |                    |
|                                | Resolution             | 100mW                |                    |
|                                | Accuracy               | 0.2%+0.2%FS          |                    |
| Dynamic mode                   |                        |                      |                    |
| CC mode                        |                        |                      |                    |
| T1&T2                          |                        | 20uS~3600S /Res:1 uS |                    |
| Accuracy                       |                        | 5uS±100ppm           |                    |
| Ascending/descending slope *4  |                        | 0.001~0.25A/uS       | 0.01~2.5A/uS *     |
| Minimum rise time *5           |                        | ≧ 30uS               | ≧ 30uS             |
| Measuring range                |                        |                      |                    |
| Read-back voltage              | Range                  | 0~18V                | 0~120V             |
|                                | Resolution             | 1 mV                 | 10 mV              |
|                                | Accuracy               | ±(0.025%+0.025%FS)   | ±(0.025%+0.025%FS) |

|                            |                      |                 |        |
|----------------------------|----------------------|-----------------|--------|
| Read-back current          | Range                | 0~12A           | 0~120A |
|                            | Resolution           | 1mA             | 10mA   |
|                            | Accuracy             | ±(0.05%+0.1%FS) |        |
| Read-back power            | Range                | 750W            |        |
|                            | Resolution           | 10mW            |        |
|                            | Accuracy             | ±(0.2%+0.2%FS)  |        |
| Protection range           |                      |                 |        |
| Overpower protection       | ≒760W                |                 |        |
| Overcurrent protection     | ≒13.2A               |                 | ≒132A  |
| Overvoltage protection     | ≒130V                |                 |        |
| Overtemperature protection | ≒85℃                 |                 |        |
| Specification              |                      |                 |        |
| Short circuit              | Current (CC)         | ≒13.2A          | 132A   |
|                            | Voltage (CV)         | 0V              | 0V     |
|                            | Resistance (CR)      | ≒10mΩ           | ≒10mΩ  |
| Input terminal impedance   | 300KΩ                |                 |        |
| Dimension                  | W439*H133.3*D580（mm） |                 |        |

| Model                       |                        | IT8814                     |                            | IT8814B                   |                            |
|-----------------------------|------------------------|----------------------------|----------------------------|---------------------------|----------------------------|
| Rated value<br>(0~40 °C)    | Input voltage          | 0~120V                     |                            | 0~500V                    |                            |
|                             | Input current          | 0~12A                      | 0~120A                     | 0~6A                      | 0~60A                      |
|                             | Input power            | 1500W                      |                            | 1200W                     |                            |
|                             | Min. operating voltage | 0.12V at 12A               | 1.2V at 120A               | 0.36V at 6A               | 3.6V at 60A                |
| Constant voltage mode       | Range                  | 0.1~18V                    | 0.1~120V                   | 0.1~50V                   | 0.1~500V                   |
|                             | Resolution             | 1mV                        | 10mV                       | 1mV                       | 10mV                       |
|                             | Accuracy               | $\pm(0.025\%+0.05\%FS)$    |                            |                           |                            |
| Constant current mode       | Range                  | 0~12A                      | 0~120A                     | 0~6A                      | 0~60A                      |
|                             | Resolution             | 1mA                        | 10mA                       | 0.1mA                     | 1mA                        |
|                             | Accuracy               | $\pm(0.05\%+0.05\%FS)$     |                            |                           |                            |
| Constant resistance mode *1 | Range                  | 0.01 $\Omega$ ~10 $\Omega$ | 10 $\Omega$ ~7.5K $\Omega$ | 0.1 $\Omega$ ~10 $\Omega$ | 10 $\Omega$ ~7.5K $\Omega$ |
|                             | Resolution             | 16bit                      |                            | 16bit                     |                            |
|                             | Accuracy               | 0.01%+0.08S *2             | 0.01%+0.0008S              | 0.01%+0.08S *2            | 0.01%+0.0008S              |
| Constant power Mode *3      | Range                  | 1500W                      |                            | 1200W                     |                            |
|                             | Resolution             | 100mW                      |                            | 100mW                     |                            |
|                             | Accuracy               | 0.2%+0.2%FS                |                            | 0.2%+0.2%FS               |                            |

| Dynamic mode                 |                       |                      |              |                      |             |
|------------------------------|-----------------------|----------------------|--------------|----------------------|-------------|
| CC mode                      |                       |                      |              |                      |             |
| T1&T2                        |                       | 20uS~3600S /Res:1 uS |              | 20uS~3600S /Res:1 uS |             |
| Accuracy                     |                       | 5uS±100ppm           |              | 5uS±100ppm           |             |
| Ascending/descending slope*4 |                       | 0.001~0.25A/uS       | 0.01~2.5A/uS | 0.0001~0.1A/uS       | 0.001~1A/uS |
| Minimum rise time *5         |                       | ≒ 30uS               | ≒ 30uS       | ≒ 20uS               | ≒ 20uS      |
| Measuring range              |                       |                      |              |                      |             |
| Read-back voltage            | Range                 | 0~18V                | 0~120V       | 0~50V                | 0~500V      |
|                              | Resolution            | 1 mV                 | 10 mV        | 1 mV                 | 10 mV       |
|                              | Accuracy              | ±(0.025%+0.025%FS)   |              |                      |             |
| Read-back current            | Range                 | 0~12A                | 0~120A       | 0~6A                 | 0~60A       |
|                              | Resolution            | 1mA                  | 10mA         | 0.1mA                | 1mA         |
|                              | Accuracy              | ±(0.05%+0.05%FS)     |              | ±(0.05%+0.05%FS)     |             |
| Read-back power              | Range                 | 1500W                |              | 1200W                |             |
|                              | Resolution            | 100mW                |              | 100mW                |             |
|                              | Accuracy              | ±(0.2%+0.2%FS)       |              | ±(0.2%+0.2%FS)       |             |
| Protection range             |                       |                      |              |                      |             |
| Overpower protection         |                       | ≒ 1550W              |              | ≒ 1250W              |             |
| Overcurrent protection       |                       | ≒ 13.2A              | ≒ 132A       | ≒ 6.6A               | ≒ 66A       |
| Overvoltage protection       |                       | ≒ 130V               |              | ≒ 530V               |             |
| Overtemperature protection   |                       | ≒ 85℃                |              | ≒ 85℃                |             |
| Specification                |                       |                      |              |                      |             |
| Short circuit                | Current (CC)          | ≒ 13.2A              | 132A         | ≒ 6.6/6A             | ≒ 66/60A    |
|                              | Voltage (CV)          | 0V                   | 0V           | 0V                   | 0V          |
|                              | Resistance (CR)       | ≒ 10mΩ               | ≒ 10mΩ       | ≒ 60mΩ               | ≒ 60mΩ      |
| Input terminal impedance     | 300KΩ                 |                      |              | 1MΩ                  |             |
| Dimension                    | W439*H133.3*D580 (mm) |                      |              |                      |             |

| Model                     |                        | IT8814C            |                   |
|---------------------------|------------------------|--------------------|-------------------|
| Rated value<br>( 0-40 °C) | Input voltage          | 0~120V             |                   |
|                           | Input current          | 0~24A              | 0~240A            |
|                           | Input power            | 1500W              |                   |
|                           | Min. operating voltage | 0.15V/24A          | 1.5V/240A         |
| Constant voltage mode     | Range                  | 0.1~18V            | 0.1~120V          |
|                           | Resolution             | 1mV                | 10mV              |
|                           | Accuracy               | ±(0.025%+0.025%FS) | ±(0.025%+0.05%FS) |
| Constant current mode     | Range                  | 0~24A              | 0~240A            |
|                           | Resolution             | 1mA                | 10mA              |
|                           | Accuracy               | ±(0.05%+0.1%FS)    | ±(0.05%+0.1%FS)   |

|                               |                       |                      |                    |
|-------------------------------|-----------------------|----------------------|--------------------|
| Constant resistance mode *1   | Range                 | 0.01Ω~10Ω            | 10Ω~7.5KΩ          |
|                               | Resolution            | 16 bit               |                    |
|                               | Accuracy              | 0.01%+0.08S *2       | 0.01%+0.0008S      |
| Constant power Mode *3        | Range                 | 1500W                |                    |
|                               | Resolution            | 100mW                |                    |
|                               | Accuracy              | 0.2%+0.2%FS          |                    |
| Dynamic mode                  |                       |                      |                    |
| CC mode                       |                       |                      |                    |
| T1&T2                         |                       | 20uS~3600S /Res:1 uS |                    |
| Accuracy                      |                       | 5uS±100ppm           |                    |
| Ascending/descending slope *4 |                       | 0.0001~0.25A/uS      | 0.001~2.5A/uS *    |
| Minimum rise time *5          |                       | ≒60uS                | ≒60uS              |
| Measuring range               |                       |                      |                    |
| Read-back voltage             | Range                 | 0~18V                | 0~120V             |
|                               | Resolution            | 0.1 mV               | 1 mV               |
|                               | Accuracy              | ±(0.025%+0.025%FS)   | ±(0.025%+0.025%FS) |
| Read-back current             | Range                 | 0~24A                | 0~240A             |
|                               | Resolution            | 1mA                  | 10mA               |
|                               | Accuracy              | ±(0.05%+0.05%FS)     |                    |
| Read-back power               | Range                 | 1500W                |                    |
|                               | Resolution            | 100mW                |                    |
|                               | Accuracy              | ±(0.2%+0.2%FS)       |                    |
| Protection range              |                       |                      |                    |
| Overpower protection          | ≒1550W                |                      |                    |
| Overcurrent protection        | ≒26.4A                | ≒264A                |                    |
| Overvoltage protection        | ≒130V                 |                      |                    |
| Overtemperature protection    | ≒85℃                  |                      |                    |
| Specification                 |                       |                      |                    |
| Short circuit                 | Current (CC)          | ≒26.4A               | 264A               |
|                               | Voltage (CV)          | 0V                   | 0V                 |
|                               | Resistance (CR)       | ≒6mΩ                 | ≒6mΩ               |
| Input terminal impedance      | 300KΩ                 |                      |                    |
| Dimension                     | W439*H133.3*D580 (mm) |                      |                    |

| Model       |               | IT8816 | IT8816B |
|-------------|---------------|--------|---------|
| Rated value | Input voltage | 0~120V | 0~500V  |

|                              |                        |                      |                |                      |               |
|------------------------------|------------------------|----------------------|----------------|----------------------|---------------|
| ( 0-40 °C)                   | Input current          | 0~24A                | 0~240A         | 0~10A                | 0~100A        |
|                              | Input power            | 3000W                |                | 2.5KW                |               |
|                              | Min. operating voltage | 0.12V/24A            | 1.2V/240A      | 0.3V/10A             | 3V/100A       |
| Constant voltage mode        | Range                  | 0.1~18V              | 0.1~120V       | 0.1~50V              | 0.1~500V      |
|                              | Resolution             | 1mV                  | 10mV           | 1mV                  | 10mV          |
|                              | Accuracy               | ±(0.025%+0.05%FS)    |                |                      |               |
| Constant current mode        | Range                  | 0~24A                | 0~240A         | 0~10A                | 0~100A        |
|                              | Resolution             | 1mA                  | 10mA           | 1mA                  | 10mA          |
|                              | Accuracy               | ±(0.05%+0.05%FS)     |                |                      |               |
| Constant resistance mode *1  | Range                  | 0.01Ω~10Ω            | 10Ω~7.5KΩ      | 0.03Ω~10Ω            | 10Ω~7.5KΩ     |
|                              | Resolution             | 16bit                |                | 16bit                |               |
|                              | Accuracy               | 0.01%+0.08S *2       | 0.01%+0.0008S  | 0.01%+0.08S *2       | 0.01%+0.0008S |
| Constant power Mode *3       | Range                  | 3000W                |                | 2.5KW                |               |
|                              | Resolution             | 100mW                |                | 100mW                |               |
|                              | Accuracy               | 0.2%+0.2%FS          |                | 0.2%+0.2%FS          |               |
| Dynamic mode                 |                        |                      |                |                      |               |
| CC mode                      |                        |                      |                |                      |               |
| T1&T2                        |                        | 20uS~3600S /Res:1 uS |                | 20uS~3600S /Res:1 uS |               |
| Accuracy                     |                        | 5uS±100ppm           |                | 5uS±100ppm           |               |
| Ascending/descending slope*4 |                        | 0.001~0.25A/uS       | 0.01~2.5A/uS * | 0.001~0.1A/uS        | 0.01~1A/uS *  |
| Minimum rise time *5         |                        | ≒ 60uS               | ≒ 60uS         | ≒ 80uS               | ≒ 80uS        |
| Measuring range              |                        |                      |                |                      |               |
| Read-back voltage            | Range                  | 0~18V                | 0~120V         | 0~50V                | 0~500V        |
|                              | Resolution             | 1 mV                 | 10 mV          | 1 mV                 | 10 mV         |
|                              | Accuracy               | ±(0.025%+0.025%FS)   |                |                      |               |
| Read-back current            | Range                  | 0~24A                | 0~240A         | 0~10A                | 0~100A        |
|                              | Resolution             | 1mA                  | 10mA           | 1mA                  | 10mA          |
|                              | Accuracy               | ±(0.05%+0.05%FS)     |                | ±(0.05%+0.05%FS)     |               |
| Read-back power              | Range                  | 3000W                |                | 2.5KW                |               |
|                              | Resolution             | 100mW                |                | 100mW                |               |
|                              | Accuracy               | ±(0.2%+0.2%FS)       |                | ±(0.2%+0.2%FS)       |               |
| Protection range             |                        |                      |                |                      |               |
| Overpower protection         | ≒ 3050W                |                      |                | ≒ 2550W              |               |
| Overcurrent protection       | ≒ 26.4A                |                      | ≒ 264A         | ≒ 11A                | ≒ 110A        |
| Overvoltage protection       | ≒ 130V                 |                      |                | ≒ 530V               |               |
| Overtemperature protection   | ≒ 85℃                  |                      |                | ≒ 85℃                |               |

| Specification            |                       |         |        |        |        |
|--------------------------|-----------------------|---------|--------|--------|--------|
| Short circuit            | Current (CC)          | ≒ 26.4A | ≒ 264A | ≒ 11A  | ≒ 110A |
|                          | Voltage (CV)          | 0V      | 0V     | 0V     | 0V     |
|                          | Resistance (CR)       | ≒ 5mΩ   | ≒ 5mΩ  | ≒ 30mΩ | ≒ 30mΩ |
| Input terminal impedance | 300KΩ                 |         |        | 1MΩ    |        |
| Dimension                | W439*H133.3*D580 (mm) |         |        |        |        |

| Model                         |                        | IT8817               |               | IT8818         |               |
|-------------------------------|------------------------|----------------------|---------------|----------------|---------------|
| Rated value<br>( 0~40 °C)     | Input voltage          | 0~120V               |               | 0~120V         |               |
|                               | Input current          | 0~36A                | 0~360A        | 0~48A          | 0~480A        |
|                               | Input power            | 4500W                |               | 6KW            |               |
|                               | Min. operating voltage | 0.15V/36A            | 1.5V/360A     | 0.15V/48A      | 1.5V/480A     |
| Constant voltage mode         | Range                  | 0.1~18V              | 0.1~120V      | 0.1~18V        | 0.1~120V      |
|                               | Resolution             | 1mV                  | 10mV          | 1mV            | 10mV          |
|                               | Accuracy               | ±(0.025%+0.05%FS)    |               |                |               |
| Constant current mode         | Range                  | 0~36A                | 0~360A        | 0~48A          | 0~480A        |
|                               | Resolution             | 1mA                  | 10mA          | 1mA            | 10mA          |
|                               | Accuracy               | ±(0.05%+0.1%FS)      |               |                |               |
| Constant resistance mode *1   | Range                  | 0.01Ω~10Ω            | 10Ω~7.5KΩ     | 0.005Ω~10Ω     | 10Ω~7.5KΩ     |
|                               | Resolution             | 16bit                |               | 16bit          |               |
|                               | Accuracy               | 0.01%+0.08S *2       | 0.01%+0.0008S | 0.01%+0.08S *2 | 0.01%+0.0008S |
| Constant power Mode *3        | Range                  | 4500W                |               | 6KW            |               |
|                               | Resolution             | 100mW                |               | 100mW          |               |
|                               | Accuracy               | 0.2%+0.2%FS          |               |                |               |
| Dynamic mode                  |                        |                      |               |                |               |
| CC mode                       |                        |                      |               |                |               |
| T1&T2                         |                        | 20uS~3600S /Res:1 uS |               |                |               |
| Accuracy                      |                        | 5uS±100ppm           |               |                |               |
| Ascending/descending slope *4 |                        | 0.001~0.25A/uS       | 0.01~2.5A/uS  | 0.001~0.25A/uS | 0.01~2.5A/uS  |
| Minimum rise time *5          |                        | ≒ 100 uS             | ≒ 100 uS      | ≒ 120 uS       | ≒ 120 uS      |
| Measuring range               |                        |                      |               |                |               |
| Read-back voltage             | Range                  | 0~18V                | 0~120V        | 0~18V          | 0~120V        |
|                               | Resolution             | 1 mV                 | 10 mV         | 1 mV           | 10mV          |
|                               | Accuracy               | ±(0.025%+0.025%FS)   |               |                |               |
| Read-back current             | Range                  | 0~36A                | 0~360A        | 0~48A          | 0~480A        |
|                               | Resolution             | 1mA                  | 10mA          | 1mA            | 10mA          |
|                               | Accuracy               | ±(0.05%+0.05%FS)     |               |                |               |
| Read-back                     | Range                  | 4500W                |               | 6KW            |               |

|                            |                     |                |        |        |       |
|----------------------------|---------------------|----------------|--------|--------|-------|
| power                      | Resolution          | 100mW          |        | 100mW  |       |
|                            | Accuracy            | ±(0.2%+0.2%FS) |        |        |       |
| Protection range           |                     |                |        |        |       |
| Overpower protection       | ≒4550W              |                |        | ≒6050W |       |
| Overcurrent protection     | ≒39.6A              | ≒396A          | ≒52.8A | ≒528A  |       |
| Overvoltage protection     | ≒130V               |                |        | ≒130V  |       |
| Overtemperature protection | ≒85℃                |                |        | ≒85℃   |       |
| Specification              |                     |                |        |        |       |
| Short circuit              | Current (CC)        | ≒39.6A         | ≒396A  | ≒52.8A | ≒528A |
|                            | Voltage (CV)        | 0V             |        |        |       |
|                            | Resistance (CR)     | ≒4mΩ           |        | ≒3mΩ   |       |
| Input terminal impedance   | 300KΩ               |                |        |        |       |
| Dimension                  | W439*H266*D590 (mm) |                |        |        |       |

| Model                       |                        | IT8817B             |               | IT8818B        |               |
|-----------------------------|------------------------|---------------------|---------------|----------------|---------------|
| Rated value<br>( 0~40 °C)   | Input voltage          | 0~500V              |               | 0~500V         |               |
|                             | Input current          | 0~12A               | 0~120A        | 0~15A          | 0~150A        |
|                             | Input power            | 3.6KW               |               | 5KW            |               |
|                             | Min. operating voltage | 0.3V/12A            | 3V/120A       | 0.3V/15A       | 3V/150A       |
| Constant voltage mode       | Range                  | 0.1~50V             | 0.1~500V      | 0.1~50V        | 0.1~500V      |
|                             | Resolution             | 1mV                 | 10mV          | 1mV            | 10mV          |
|                             | Accuracy               | ±(0.025%+0.05%FS)   |               |                |               |
| Constant current mode       | Range                  | 0~12A               | 0~120A        | 0~15A          | 0~150A        |
|                             | Resolution             | 1mA                 | 10mA          | 1mA            | 10mA          |
|                             | Accuracy               | ±(0.05%+0.05%FS)    |               |                |               |
| Constant resistance mode *1 | Range                  | 0.03Ω~10Ω           | 10Ω~7.5KΩ     | 0.03Ω~10Ω      | 10Ω~7.5KΩ     |
|                             | Resolution             | 16bit               |               | 16bit          |               |
|                             | Accuracy               | 0.01%+0.08S *2      | 0.01%+0.0008S | 0.01%+0.08S *2 | 0.01%+0.0008S |
| Constant power Mode *3      | Range                  | 3.6KW               |               | 5KW            |               |
|                             | Resolution             | 100mW               |               | 100mW          |               |
|                             | Accuracy               | 0.2%+0.2%FS         |               | 0.2%+0.2%FS    |               |
| Dynamic mode                |                        |                     |               |                |               |
| CC mode                     |                        |                     |               |                |               |
| T1&T2                       |                        | 20uS~3600S /Res:1uS |               |                |               |

|                               |                     |                    |            |               |            |
|-------------------------------|---------------------|--------------------|------------|---------------|------------|
| Accuracy                      |                     | 5uS±100ppm         |            |               |            |
| Ascending/descending slope *4 |                     | 0.001~0.1A/uS      | 0.01~1A/uS | 0.001~0.1A/uS | 0.01~1A/uS |
| Minimum rise time *5          |                     | ≒80uS              |            | ≒100 uS       |            |
| Measuring range               |                     |                    |            |               |            |
| Read-back voltage             | Range               | 0~50V              | 0~500V     | 0~50V         | 0~500V     |
|                               | Resolution          | 1 mV               | 10 mV      | 1 mV          | 10 mV      |
|                               | Accuracy            | ±(0.025%+0.025%FS) |            |               |            |
| Read-back current             | Range               | 0~12A              | 0~120A     | 0~15A         | 0~150A     |
|                               | Resolution          | 1mA                | 10mA       | 1mA           | 10mA       |
|                               | Accuracy            | ±(0.05%+0.05%FS)   |            |               |            |
| Read-back power               | Range               | 3.6KW              |            | 5KW           |            |
|                               | Resolution          | 100mW              |            | 100W          |            |
|                               | Accuracy            | ±(0.2%+0.2%FS)     |            |               |            |
| Protection range              |                     |                    |            |               |            |
| Overpower protection          |                     | ≒3650W             |            | ≒5050W        |            |
| Overcurrent protection        |                     | ≒13.2A             | ≒132A      | ≒16.5A        | ≒165A      |
| Overvoltage protection        |                     | ≒530V              |            | ≒530V         |            |
| Overtemperature protection    |                     | ≒85℃               |            | ≒85℃          |            |
| Specification                 |                     |                    |            |               |            |
| Short circuit                 | Current (CC)        | ≒13.2A             | ≒132A      | ≒16.5A        | ≒165A      |
|                               | Voltage (CV)        | 0V                 |            |               |            |
|                               | Resistance (CR)     | ≒25mΩ              |            | ≒20mΩ         |            |
| Input terminal impedance      | 1MΩ                 |                    |            |               |            |
| Dimension                     | W439*H266*D590 (mm) |                    |            |               |            |

\*1.The voltage/current input is no less than 10%FS (FS indicates the full scope).

\*2.The scope of read-back resistance is  $(1/(1/R+(1/R)*0.01\%+0.08), 1/(1/R-(1/R)*0.01\%-0.08))$ .

\*3.The voltage/current input is no less than 10%FS.

\*4.Ascending/descending slope: 10%-90% current ascending slope from 0 to maximum current

\*5.Minimum rise time: 10%-90% current rise time

\*The above specifications may be subject to change without prior notice.

## 4.2 Additional features

Memory capacity: 100 groups.

Recommended calibration frequency: 1 time/year.

Cooling method: fan.

Fan control temperature:

|             |            |             |            |                                                   |
|-------------|------------|-------------|------------|---------------------------------------------------|
| Temperature | 40°C       | 50°C        | 70°C       | 85°C                                              |
| Fan status  | First gear | Second gear | Third gear | Temperature protection (OH) and load is shut off. |

# Chapter5 References of Load Communication Interfaces

IT8800 series electronic load is provided with two communication interfaces to communicate with a computer for selection, including RS232 and USB.

## 5.1 RS232 interface

Cable connection load with both ends of COM interface (DB9) and computer. Composite key **[Shift] + 5** on front board can be used to enter system menu for activation.

In RS-232 interface, all SCPI commands can be used for programming. If RS-232 interface is selected, in accordance with internal connection of data terminal equipment (DTE) and data communication equipment (DCE) as defined in EIA RS-232, the load is connected to another DTE (e.g., PC COM interface) with direct-connected Modem cable.



### NOTE

The rear board of IT8800 series has two COM interfaces. The upper 9-pin COM interface connector is RS232 interface; and the lower 9-pin COM interface is external signal control interface.

RS-232 setting in procedure should be consistent with that in system menu of front board. Press composite key **[Shift] + 5** to change (if necessary). Send a ^C or ^X character string to the load to pause data transmission. It will clear any uncompleted operation and waive any uncompleted output.

### RS-232 data format

RS-232 data comprises start bit, odd and even parity check bit, stop bit and 8-bit data bit. Start bit and stop bit are not editable. However, next odd or even item can be selected by front board **[Shift] + 5**. The odd and even items are saved in NVM.


### Baud rate

Through front board **[Shift] + 5**, the user may select one Baud rate saved in NVM: 4800 9600 19200 38400 57600 115200

### RS-232 Connection

Use RS-232 cable with DB-9 interface because the RS-232 serial port can be connected controller (e.g. PC) serial port. Do not use modulating cable of air-conditioner. Refer to Table 2-2 for plug pin.

If your computer is provided with a RS-232 interface with DB-25 plug, a cable and a adapter with DB-25 plug (one end) and DB-9 plug (the other end) are required (not the modulating cable of the air-conditioner).



| Base pin number | Description            |
|-----------------|------------------------|
| 1               | No conjunction         |
| 2               | TXD, data transmission |
| 3               | RXD, data receiving    |
| 4               | No conjunction         |
| 5               | GND, grounding         |
| 6               | No conjunction         |
| 7               | CTS, clear to send     |
| 8               | RTS, request to send   |
| 9               | No conjunction         |

### RS-232 troubleshooting:

In case of connection failure of RS-232, perform following check:

- Check if the computer and load are provided with same Baud rate, parity check bit, data bit and flow control. The power shall be configured with one start bit (fixed) and one stop bit (fixed).
- Just as described in the RS-232 connector, correct interface cable or adapter shall be adopted. Note: even if the cable is equipped with right plug, internal wiring may be incorrect.
- The interface cable must be connected to the correct serial port (COM1, COM2, etc.) of the computer.

### Setting of communication

Before communication operation, be sure to match load and PC parameters (as follows).

Baud rate: 9600 (4800/9600/19200/38400/57600/15200). You may enter system menu through the board to set communication Baud rate.

Data bit: 8 bits

Stop bit: 1 bit

Check: (none, even, odd)

EVEN All all 8 data bits have even-parity check

ODD All all 8 data bits have odd-parity check

NONE All all 8 data bits have no check

Local address: (0-31, factory set value: 0)

|           |             |             |          |
|-----------|-------------|-------------|----------|
| Start Bit | Parity=None | 8 Data Bits | Stop Bit |
|-----------|-------------|-------------|----------|

## 5.2 USB Interface

Connect the load and the computer using a cable with two USB interfaces (each end). All functions of the load can be programmed via USB.

The functions of load USB488 interface are as follows:

- The interface is 488.2 USB488 Interface.

- The interface receives requests of REN\_CONTROL, GO\_TO\_LOCAL and LOCAL\_LOCKOUT.
- The interface receives the command MsgID=TRIGGER USBTMC and conveys the TRIGGER command to the functional layer.

The functions of load USB488 device are as follows:

- Capable to read all common SCPI commands.
- SR1 enabled.
- RL1 enabled.
- DT1 enabled.

### 5.3 GPIB interface(Only for IT8800(G) series)

Firstly, connect load GPIB interface and computer GPIB card through IEEE488 bus and ensure sufficient contact. Tighten them with screws. Set address. Load address range: 0-31. Press **[Shift] + 5** to enter system menu functions. Press Left/Right key to find Communication. Select GPIB and set address. Input address and press **[Enter]** for confirmation. The load works by setting GPIB address on front board. GPIB address is saved in NVM.

## Appendix

### Specifications of Red and Black Test Lines

ITECH provides you with optional red and black test lines, the user can choose the company's test line for testing. For specifications of ITECH test lines and maximum current values, refer to the table below.

| Model           | Description                                          |
|-----------------|------------------------------------------------------|
| IT-E30110-AB    | 1kV/10A/1m*2pcs Alligator clips-Banana plugs         |
| IT-E30110-BB    | 1kV/10A/1m*2pcs Banana plugs-Banana plugs            |
| IT-E30110-BY    | 1kV/10A/1m*2pcs Banana plugs-Y-type terminals        |
| IT-E30312-YY    | 500V/30A/1.2m*2pcs Y-type terminals-Y-type terminals |
| IT-E30320-YY    | 500V/30A/2m*2pcs Y-type terminals-Y-type terminals   |
| IT-E30615-OO    | 500V/60A/1.5m*2pcs Ring terminals-Ring terminals     |
| IT-E31005LIC-OO | 600V/100A/0.5m*2pcs Ring terminal low inductance     |
| IT-E31010LIC-OO | 600V/100A/1m*2pcs Ring terminal low inductance       |
| IT-E31020LIC-OO | 600V/100A/2m*2pcs Ring terminal low inductance       |
| IT-E31040LIC-OO | 600V/100A/2m*2pcs Ring terminal low inductance       |
| IT-E31220-OO    | 500V/120A/2m*2pcs Ring terminals-Ring terminals      |
| IT-E31250-OO    | 500V/120A/5m*2pcs Ring terminals-Ring terminals      |
| IT-E32410-OO    | 500V/240A/1m*2pcs Ring terminals-Ring terminals      |
| IT-E32420-OO    | 500V/240A/2m*2pcs Ring terminals-Ring terminals      |
| IT-E32450-OO    | 500V/240A/5m*2pcs Ring terminals-Ring terminals      |
| IT-E3301020-OO  | 3kV/100A/2m*2pcs Ring terminals-Ring terminals       |
| IT-E3301050-OO  | 3kV/100A/5m*2pcs Ring terminals-Ring terminals       |
| IT-E3302420-OO  | 3kV/240A/2m*2pcs Ring terminals-Ring terminals       |
| IT-E3302450-OO  | 3kV/240A/5m*2pcs Ring terminals-Ring terminals       |
| IT-E3303620-OO  | 3kV/360A/2m*2pcs Ring terminals-Ring terminals       |
| IT-E3304020-OO  | 3kV/400A/2m*2pcs Ring terminals-Ring terminals       |
| IT-E33620-OO    | 500V/360A/2m*2pcs Ring terminals-Ring terminals      |
| IT-E33650-OO    | 500V/360A/5m*2pcs Ring terminals-Ring terminals      |
| IT-E34020-OO    | 500V/400A/2m*2pcs Ring terminals-Ring terminals      |
| IT-E34520-OO    | 500V/450A/2m*2pcs Ring terminals-Ring terminals      |
| IT-E35030-OO    | 500V/360A/3m*2pcs Ring terminals-Ring terminals      |
| IT-E36530-OO    | 500V/650A/3m*2pcs Ring terminals-Ring terminals      |

For maximum current of AWG copper wire, refer to table blow.

| AWG                           | 10 | 12 | 14 | 16 | 18 | 20 | 22 | 24  | 26  | 28  |
|-------------------------------|----|----|----|----|----|----|----|-----|-----|-----|
| The Maximum current value( A) | 40 | 25 | 20 | 13 | 10 | 7  | 5  | 3.5 | 2.5 | 1.7 |

**Note:** AWG (American Wire Gage), it means X wire ( marked on the wire).

**The table above lists current capacity of single wire at working temperature of 30°C. For reference only.**

## **Contact Us**

Thanks for purchasing ITECH products. In case of any doubts, please contact us as follows:

1. Visit ITECH website: [www.itechate.com](http://www.itechate.com).
2. Select the most convenient contact method for further information.